



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001




No. F6/DFS/MS/2025/Hospital/ 280

Dated: 02/06/2025

FIRE SAFETY CERTIFICATE

Certified that the Aggarwal Dharmarth Hospital Society located at 24/9, Shakti Nagar, Delhi-110007 comprised of Ground, Mezzanine & 03 upper floors only owned/ occupied by Aggarwal Dharmarth Hospital Society, complied with. The premises was inspected by the officers concerned of this department on 15/05/2025 in the presence of Smt. Poonam (Attendant) and found that the said premises have deemed complied with 12 bare minimum fire safety measures and the building/ premise is fit for occupancy class "Institutional Group C" with effect from 02/06/2025 for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 02/06/2025 at New Delhi by


29/5/2025
(Virender Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Dr. Sandeep Kr. Aggarwal, (Medical Superintendent- Nursing Home), Director General of Health Services, 3rd floor, Delhi Government Dispensary Building, S-1, School Block, Shakarpur, Delhi-110092.
2. The Authorized Signatory, M/s Aggarwal Dharmarth Society Hospital located at 24/7, Shakti Nagar, Delhi-110007

Conditions for the validity of Fire Safety Certificate:

1. The Terrace shall be not used for any hospital purpose.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Aggarwal Dharmarth Hospital Society at 24/9, Shakti Delhi-110007.
2. Type of Occupancy : Institutional
3. Composition of building : Ground- pharmacy, sample collection, casualty room, reception Ayurvedic room, Mezz floor- small meeting room, 1st floor- Deferent types OPD cabin, 2nd floor- lab, physiotherapy, OT, Labor room, ICU, NICU & 3rd floor- 04 Pvt. Rooms, 02 semi Pvt. Rooms, Economic ward & Nursing counter.
4. Type of Case : New Case
5. Details of previous NOC : F6/MS/DFS/2005/MR/2506/HR/Con./173 dated 05/10/2007
6. Fire Safety directives letter No : 12 basic minimum fire safety measures
7. Date of inspection : 15/05/2025
8. Name of the Inspecting Officers : DO (NW) & ADO (RN)
9. Name and designation of officers from the building side : Smt. Poonam (Attendant)
10. Year of Construction : 1968
11. Applicant's letter No. : Letter No. F.24/75/Central/DGHS/NHC/2025/104 Dated 17/04/2025

S. No	Minimum Standards on fire prevention and fire safety	12 basic minimum fire safety measures	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	Provided	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Old Case	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	Old Case	1.20m & 80cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	Old Case	2nos	MR
	e. Width of Corridor	Old Case	1.80m	MR
	f. Door Size	Old Case	01m	MR
3	Fire Extinguishers			
	• Total numbers	12nos	Provided	MR
	• Types	ISI marked	Provided	MR
	• IS marking	Required	Provided	MR
4	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

5	Automatic fire detection and alarming system. ¹¹¹⁹			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke/Heat	Provided	MR
		G.F	Provided	MR
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
6	Public Address System.	Required	Provided	MR
7	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor 	NA	NA	NA
		NA	NA	NA
8	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100mm	Provided	MR
		01nos	Provided	MR
		01nos	Provided	MR
9	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
		1620 LPM	Provided	MR
		40m	Provided	MR
		01	Provided	MR
		180 LPM	Provided	MR
		40m	Provided	MR
		NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
		450 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
10	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	50,000 LTR	Provided	MR
		NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		10,000 LTR	Provided	MR
11	Exit Signage.	Required	Provided	MR
12	Standby power supply	Required	Provided	MR

The fire protection systems provided in the building were tested/ checked and found in working order at the time of inspection.

Keeping in view the substantial satisfactory compliance of 12 Basic minimum fire safety measures it is recommended to renew fire safety certificate under Delhi fire service Act-2007 & Rules 2010.

Signature of the inspection Officer
Name :- D.B. Mukharjee
Designation:- DO/NWD

Signature of the Inspecting Officer
Name :- C.L. Meena
Designation:- ADO/RN

By cfo /wz

dy 21/5

CFO /
23/5/2015

Director /
29/5/2015

ADG/R

As approved F.T. letter is put up for your signature please.

28/05/2015
ADO(RN)

Director (PS) on m/p

CFO /
29/5/2015

ms cell