

C-75

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F.6/DFS/MS/2025/NDZ/ 216 (A)

Dated 09/05/2025

To,

Mr. Sunil K Jain (Vice President),  
Aggrawal Plaza, Plot No 13A/4, Asaf Ali Road,  
Delhi - 110002.

**Sub:- Regarding renewal of FSC in r/o Aggrawal Plaza , Plot No 13A/4, Asaf Ali Road, Delhi - 110002.**

Sir,

This has reference to your letter no. nil dated 15.04.2025, on the subject cited above, it is to inform that the site was inspected by the officer concerned of this department on 06/05/2025 in the presence of Mr. Sunil Jain and the following shortcomings were observed: -

1. Fire check door found removed at some floors from the staircase.
2. Lift & lift lobby pressurization system found non functional.
3. Diesel pumps found non functional.

In view of above, request for renewal of fire FSC is rejected. The occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

The Commissioner, North MCD, Civic Centre, New Delhi.