

C/38

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE**  
**CONNAUGHT PLACE: NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/ 527

Dated: 17 / 06 / 2025

To

The Principal,  
Fr. Agnel Sr. Sec. School,  
Gautam Nagar, New Delhi-110049

Sub: Renewal of Fire Safety Certificate in r/o Fr. Agnel School located at Gautam Nagar, New Delhi-110049



Sir,

Please refer to your letter No FASD/SO/ADM-II/716 dated 09/04/2025, received through outdoor diary No. 501 dated 11/04/2025. In this connection, it is to inform you that the above said premise was visited by the officer concerned of this department on 02/06/2025 in the presence of Sh. Robert Samuel (Security Incharge) to verify the availability and operability of fire safety measures. During course of inspection, the shortcomings observed are as below.

1. One of the exits/stairs found blocked in basement and being used for table tennis.
2. Terrace level fire pumps were not automatic in action.
3. Exit signage found removed at some locations.
4. Corridors on upper floors found encroached by erecting office cabins.

In view of above, application for renewal of fire safety certificate is rejected. The occupancy of the building in the absence of valid Fire Safety Certificate shall be at the risk and liability of the owner/occupier.

Yours faithfully,

  
12.6.2025  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service  


Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054