**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/Assembly/SZ/2025/482 Dated: 10/11/2026

To

The Director,
All India Institute of Medical Science,
Ansari Nagar, New Delhi-110029.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Dinning Block at AIIMS Complex, Ansari Nagar, New Delhi-29.

Sir,

With reference to the DFS online application no. 52026051402915 on the subject cited above, it is informed that the said Dinning Block was visited by officer concerned of this department on 27.10.2026 in the presence of manager and following shortcomings were observed:

1. Electrical shaft found unsealed vertically & horizontally at some levels.
2. All water-based Systems like Hose-reel, Automatic Sprinkler System, Internal & Yard Hydrant Systems are found non-functional.
3. Fire Pumps are found removed.
4. Pressurization of Lift Shaft & lift Lobby found removed.
5. Underground water tank of 2,00,000 liters for firefighting found removed.
6. Lift signages found removed.

In view of above shortcomings, the application of issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(A. K. Malik)
Chief Fire Officer

Copy to:-

1. The Fire Officer, All India Institute of Medical Sciences, Ansari Road, New Delhi-29.