



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Audi/2025/SZ/ 60

Dated: 10/02/2025

To

Sh. Manoj Mehta (Gp. Capt.),
Director, Air Force Auditorium,
Subroto Park, New Delhi-110010

Sub: Renewal of Fire Safety Certificate in r/o M/s Air Force Auditorium located at Subroto Park, New Delhi-110010

Sir,

This has a reference to your letter No. Air HQ/E&CS/19120/20/Audi dated 14/01/2025, received through outdoor diary No. 11482 dated 16/01/2025. In this connection, it is to inform you that the auditorium premise was inspected by the officer concerned of this department on dated 31/01/2025 in the presence of Sh. A. R. Rawat (Wing Cdr.), from fire safety point of view. During course of inspection, the shortcomings observed are as below.

1. Smoke management system provided in auditorium found not integrated with MCPs Detectors/Sprinklers.
2. Automatic fire detection system (Beam Detector) found non-functional.
3. Exit signage found removed at some location.

In view of the above, the application for renewal of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety certificate/arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Joint Commissioner of Police (Lic.), 1st Floor, Police Station Defence Colony, New Delhi-110049