

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Audi/2025/SZ/106

Dated: 05/03/2025

FIRE SAFETY CERTIFICATE

Certified that **M/s Air Force Auditorium at Subroto Park, Delhi Cantt. New Delhi 110010** comprised of Basement, Ground Plus one upper Floor, **Auditorium at Ground floor only without balcony & Basement totally separate** owned/occupied by Indian Air Force was issued FSC by this department vide letter no. F6/DFS/MS/Auditorium/2022/SZ/97 dated 07/03/2022. The premise was re-inspected by the officer concerned of this department on 03.03.2025 in the presence of Capt. Manoj Mehta (Director AF Auditorium) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy **Group "D" Assembly Building (Auditorium)** with effect 05/03/2025 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on 05/03/2025 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. Gp Capt Manoj Mehta, M/s Air Force Auditorium at Subroto Park, Delhi Cantt. New Delhi 110010.
2. The Addl. Commissioner of Police, Lic/Branch, 1st Floor PS Defence Colony, New Delhi 110049.

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The basement shall be used as per the provisions of BBL-/NBC Part- IV.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1. Name & address of the building: M/s Air Force Auditorium Subroto Park Delhi Cantt. New Delhi- 110010.
2. Type of Occupancy : Group "D" Assembly Building [Auditorium at GF only]
Without balcony & Basement is totally separate)
3. Type of Case : Renewal
4. Comprised of : Basement, Ground plus One upper floor
5. Details of Previous NOC : F6/DFS/MS/Auditorium/2022/SZ/97 dated 07/03/2022
6. Fire Safety directives letter No : Nil
7. Date of inspection : 03/03/2025
8. Name of Inspecting Officer : Sh. Rajesh Kumar ADO (BCP)
9. Name and designation of officers from the building side : Capt. Manoj Mehta (Director AF Auditorium)
10. Year of Construction : 1990
11. Applicant's letter No. : Air-HQ/E&CS/19120/20/Aud dated 14/02/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	9m 5m NA	Provided Provided NA	MR MR NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	04 Nos -NA-	Provided -NA-	MR -NA-
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.5m -NA-	1.8m, 1.9m, 1m & 1m -NA-	MR -NA-
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	Required -NA-	Provided -NA-	MR -NA-
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1m	08 No provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Required Required -NA- -NA- -NA-	Provided in basement Provided -NA- -NA- -NA-	MR MR -NA- -NA- -NA-
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	-NA- 12 ACPH	-NA- Exhaust fans	-NA- MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	38 No's ABC/W.CO ₂ /CO ₂ Required	Provided Provided Provided	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	05 Nos 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel 	Smoke & Heat Required	Provided Ground Floor	MR MR

	<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power Hooters' Location 	-NA- Required Required	-NA- Provided All Floors Provided	-NA- MR MR MR
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floors Sprinkler above false ceiling 	-NA- Required -NA-	-NA- Provided -NA-	-NA- MR -NA-
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	08 Nos 08 Nos	Provided Provided	MR MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	1620 LPM 70m 01 240 LPM 70m -NA- -NA- Required	Provided Provided Provided Provided Provided -NA- -NA- Provided	MR MR MR MR MR -NA- -NA- MR
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	-NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	1,00,000 ltrs Required Required Required 10,000 Lts. Required	Provided Provided Provided Provided Provided Provided	MR MR MR MR MR MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	-NA- -NA-	-NA- -NA-	-NA- -NA-
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Battery backup 	Required -NA- Required Required	Provided -NA- Provided Provided	MR -NA- MR MR

	• Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/Auditorium/2022/SZ/97 dated 07/03/2022, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Signature
31/3/2022

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (SD)

Signature 4/3/20
Signature
Signature 28/3/2022
Signature
5/3/22
Signature