

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F.6/DFS/MS/2025/452

Dated 10/09/2025

To,

Sh. Sandeep Kumar Srivastava,
Under Secretary, (Gen Admn),
AIU House, 16, Comrade Indrajit Gupta Marg,
Kotla Marg New Delhi-110002.

Sub:-Regarding renewal of FSC in r/o Association of Indian Universities (AIU) House, 16,
Comrade Indrajit Gupta Marg, (Kotla Marg) New Delhi-110002.


Sir,

This has reference to your letter no. GA/Renov/2025/2021 dated 09/07/25, on the subject cited above. In this regard the site was inspected by the officer concerned of this department on 19/08/2025 in the presence of Sh. Sandeep Shrivastav and the following shortcomings were observed:-

1. Electric shaft not sealed properly.
2. Smoke Management system in basement is not integrated with detection/ alarm system.
3. Detectors are not provided in lift machine room.
4. Exit signage's are inadequate required to be installed at prominent places.
5. Lift signage's not provided.
6. All the wooden paneling is required to be treated with fire retardant paint and certificate of the same is also required to be submitted .

In view of above shortcomings, renewal of FSC cannot be considered at this stage. Therefore, you are requested to rectify the above shortcomings at the earliest.

Yours faithfully


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Chief Architect, New Delhi Municipal Council, Palika Kendra, New Delhi.