



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/124

Dated: 24 / 02 / 2025

To

The Manager,
Akshay Public School
Sector-16B, Dwarka,
Kakrola, New Delhi-110078

Sub: **Regarding renewal of Fire Safety Certificate in r/o Akshay Public School, Sector-16B, Dwarka, Kakrola, New Delhi.**

Sir,

This has a reference to your letter received through outdoor diary No. 11794 dated 27/01/2025, on the subject above. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on 13/02/2025 in your presence from fire safety point of view. During the course of inspection, the shortcomings observed are as below: -

1. Hose reel found non-functional, nozzle missing.
2. Terrace pump found non-functional.
3. Exit signages found removed at some locations.

In view of above, application for renewal of fire safety certificate is rejected. You are requested to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.