

9/26

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No.F.6/DFS/MS/EH/NDZ/2026 | 444

Dated. 06 / 05 / 2026

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the Name & Style of M/s AL Jawahar Restaurant, Property No. 8, 12 and 15, Bazaar Matia Mahal, Jama Masjid Delhi 110006 in the building comprised of Ground + Mezzanine + 3 upper floor only (Restaurant at GF & Mezzanine only, first floor (owner residence) 2nd & 3rd (Guest House) was granted FSC by this department vide letter No.F6/DFS/MS/EH/NDZ/2023/206 dated 30/06/2023. Now the building/ premises was re-inspected by the officer concerned of this department on 23.04.2026 in presence of Mr. Javed (Manager) and found that the premises/building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premise is fit for occupancy class **Group-D Assembly Building** (Restaurant at GF & Mezzanine only) with effect from 06 / 05 / 2026 valid up to three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 06 / 05 / 2026 at New Delhi by


4/5/26

(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, Dr. SPM Civic Centre, New Delhi – 110002, w.r.to ID No. 2024040604344 dated 14/04/2026:- to kindly ensure the occupancy as detailed above & deviation, if any)
2. The Licensee, M/sAL Jawahar Restaurant, Property No. 8, 12 and 15, Bazaar Matia Mahal, Jama Masjid Delhi 110006

Conditions for the validity of Fire Safety Certificate: -

1. This FSC is valid for Restaurant/Eating House at Ground and Mezzanine Floor only.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.
9. The occupancy of any floor above 2nd floor not allowed as per clause 7.31 in UBBL-2016

11-15

INSPECTION REPORT				
1	Name & Address of the Building	M/s Al Jawahar Restaurant, Property No. 8, 12 and 15, Bazaar Matia Mahal, Jama Masjid Delhi 110006.		
2	Type of Occupancy	Group-D Assembly Building. (Eating House)		
3	Building Comprised of	Ground+ Mezzanine +3 upper floor only (Restaurant at GF & Mezzanine only, 1 st floor (owner residence) 2 nd & 3 rd Guest House)		
4	Type of Case	Renew (Old case)		
5	Details of Previous FSC	F6/DFS/MS/EH/NDZ/2023/206 dated 30/06/2023		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	23/04/2026		
8	Name of the Inspecting Officers	Sh. SumanKumarADO (SPM)		
9	Name & Designation of Officers from the building side	Sh. Javed (Manager)		
10	Year of construction	1965		
11	Applicant letter No.	Applicationno. 2024040604344 dated 14/04/2026		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL/ NBC- 2016	Provided at Site	Remarks MR/NM R
1	Access to Building.			
	• Road width	06 mtr	09 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	02 Nos	MR
	➤ Basement floor.	N/A	N/A	N/A
	b) Width of Staircase			
	➤ Upper floors	1.50 mtr each	1.60 m & 1.50 m	MR
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	01	01	MR
	e) Width of corridor	1.5 mtr	1.5 mtr	MR
	f) Door size	2 x 1.50 mtr	2 x 1.50 mtr	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	• Basement	NA	N/A	N/A
	• Upper floors	Required	Provided Exhaust fan	MR

N-16

5	Fire Extinguishers.			
	• Total numbers	04Nos	06Nos	MR
	• Types	ABC/CO ₂	ABC & CO ₂	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	• Type of detectors	N/A	Provided	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Ground/ upper floors.	N/A	Provided	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants.			
	• Size of Riser/Down-comer	100 mm	Provided	MR
	• Number of Hydrant per floor	One	Provided	MR
	• Hose box.	One	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.			
		N/A	N/A	N/A
13	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby Pump head.	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping.	N/A	N/A	N/A
	➤ Pump house access.	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump.	450 LPM	Provided	MR
	➤ Head of pump.	30m	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14	Captive water storage for fire fighting.			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	Required	Provided	MR

N-17

	➤ Access to tank.	Required	Provided	MR
	• Overhead tank capacity.	20,000 Ltrs	24,000 Ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room.			
	• Detector system panel.	N/A	N/A	N/A
	• Flow switch panel.	N/A	N/A	N/A
	• PA system panel.	N/A	N/A	N/A
	• Battery backup.	N/A	N/A	N/A
	• Building floor plan.	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, if approved, we may renew the FSC issued vide letter No F6/DFS/MS/EH/NDZ/2023/206 dated 30/06/2023. under Rule 35 (6) of the Delhi Fire Service Rules, 2010

DO (CD)

30/04/26

CFO (NDZ)

Principal Director

NDZ/MS
30/04/26

CFO to SPM

CFO (NDZ)

30/04/26

Addl SPM

30/04/26

Signature of the Inspecting Officer
Name Suman Kumar
Designation ADO (SPM)

NDZ/MS
30/04/26