

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/GH/NDZ/2025/361
To,

Dated: 22 / 08 / 2025

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding renewal of NOC from fire safety point of view in respect of M/s Al Saudia Guest House located at 954, Gali Shyam Lal, Matia Mahal, Jama Masjid, Delhi- 110006.

Sir,

Please refer to your online application no. 2025072111668 dated 22.07.2025, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 08/8/2025 in the presence of Mr. Sazzad (Manager) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the said guest house comprised of Basement + Ground + 06 upper floors: Basement - (not in use), ground floor - (03 guest rooms + reception), 1st floor - (03 guest rooms), 2nd floor- (03 guest rooms), 3rd floor - (owner residence) & 4th to 6th floor - (not in use). FSC was earlier granted by this department vide letter No. F6/DFS/MS/GH/NDZ/2022/540 dated 13.12.2022 for total 09 guest rooms upto 2nd floor only. Fire safety arrangements such as Fire Extinguishers, MOEFA etc provided. **However the following shortcomings were observed.**

1. First aid hose reels are provided but not functional.
2. Automatic fire detection and alarming system provided but not functional.
3. Terrace level fire pump capacity of 225 LPM is provided but not on automode.
4. Exit signages are found removed at some places.

In view of above Shortcomings, the **application for renewal of Fire safety Certificate is cannot considered at this stage & rejected.** The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully,


(Vinendra Singh)
Chief Fire Officer

Copy to: -

1. Online application ID No. 2025072111668 dated 22.07.2025.
2. Al Saudia Guest House at 954, Gali Shyam Lal, Matia Mahal, Jama Masjid, Delhi- 110006.