

C/90

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 367

Dated:-02./09./2025

To,

The Commissioner, MCD,
Civic Centre, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Alam Panah The Royal Guest House at 2620-21, Bara Dari, Ballimaran, Delhi -06.


Sir,

This has reference to on line ID No. 2025080712326 dated 07.08.2025, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 23/08/2025 in the presence of Mr. Mohamad Ali and following shortcomings were observed: -

1. Hose reel not provided at first floor.
2. PA system found non functional.

In view of above shortcomings the case is rejected and Fire Safety Certificate (FSC) cannot be issued due to above shortcomings. Therefore, you are requested to direct the applicant to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully



(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to :

1. The DHO/MHO, MCD (Public Health), 19th floor , Civic Centre, New Delhi.
2. The Manager, Alam Panah The Royal Guest House at 2620-21, Bara Dari, Ballimaran, Delhi -06.