



No. F6/DFS/MS/School/NDZ/2025/ 683

Dated: 21/05/2025

FIRE SAFETY CERTIFICATE

Certified that **Alfalalah Islamic School** located at **Veer Abdul Hameed Road, B - Block, North Ghonda, Delhi - 110053**, school is running on ground plus one upper floor of the building comprised of ground plus two upper floors owned/ occupied by **Alfalalah Islamic School** was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2022/NDZ/123 dated 07/02/2022. The school building was re-inspected by the officer concerned of this department on 14/05/2025 in presence of Mr. Shaquib Yasin (Manager) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. 262 - 362 dated 17/01/2005 and the school is fit for occupancy class **(Group - B) "Educational Building" for ground plus one upper floor only** with effect from 21/05/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010. Subject to conditions, printed overleaf.

Issued on 21/05/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Joint Director of Education, (Land & Estate) Director of Education, Lucknow Road, Delhi - 110054.
2. The Principal, Alfalah Islamic School located at Veer Abdul Hameed Road, B - Block, North Ghonda, Delhi - 110053.

Conditions for the validity of Fire Safety Certificate

1. Fire Safety Certificate is valid for Ground plus one upper floor only.
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
7. At the time of inspection second floor was vacant not for used any purpose.
8. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

| | | | | |
|-------|--|---|----------------------|----------------|
| 1 | Name & address of the building | Alfalsh Islamic School located at Veer Abdul Hameed Road, B- Block, North Ghonda, Delhi - 110053. | | |
| 2 | Building is comprised of | Ground two upper floors (School is running on G+1 only) | | |
| 3 | Type of occupancy | Educational Building | | |
| 4 | Type of case | Renewal | | |
| 5 | Details of previous FSC | F6/DFS/MS/School/2022/NDZ/123 dated 07/02/2022 | | |
| 6 | Fire safety directives letter no. | Circular No. 262 - 362 dated 17/01/2005 | | |
| 7 | Date of inspection | 14/05/2025 | | |
| 8 | Name of the inspecting officers | Yashwant Singh Meena ADO (Laxmi Nagar) | | |
| 9 | Name of the designation of officer from the building side | Mr. Shaquib Yasin (Manager) | | |
| 10 | Year of construction | 1983 | | |
| 11 | Applicant's letter no. | Outdoor Diary No.1448 dated 07/05/2025 | | |
| S. No | Minimum standard of fire prevention and fire safety U/R 33 | Circular Requirement | Provided at site | Remarks MR/NMR |
| 1. | Access to Building: | | | |
| A | Road width | 6.0 mtrs. | 4.0 mtrs. | MR (old case) |
| B | Gate width | N/A | N/A | N/A |
| C | Width of internal road | N/A | N/A | N/A |
| 2. | Number, Width, Type and Arrangement of Exits: | | | |
| A | Number of staircases | | | |
| a | Upper floor | 01 no. | 02 nos. | MR |
| b | Basement | N/A | N/A | N/A |
| B | Width of staircases | | | |
| a | Upper floor | 1.50 mtrs. | 1.1 mtrs & 0.75 mtrs | MR |
| b | Basement | N/A | N/A | N/A |
| C | Protection of exits | | | |
| a | Fire check door | N/A | N/A | N/A |
| b | Pressurization | N/A | N/A | N/A |
| D | No. of continuous staircases to terrace | 01 no. | 01 no. | MR |
| E | Width of corridor | 1.50 mtrs. | 1.50 mtrs. | MR |
| F | Door size | 1.0 mtr. | 1.0 mtr. | MR |
| 3. | Compartmentation: | | | |
| A | Fire check door | NA | NA | NA |
| B | Sealing of electrical shafts | N/A | N/A | N/A |
| C | Fire rating of shaft door | N/A | N/A | N/A |
| D | Water curtain | N/A | N/A | N/A |
| E | Fire dampers | N/A | N/A | N/A |
| 4. | Smoke Management System: | | | |
| A | Basement | N/A | N/A | N/A |
| B | Upper floor | N/A | N/A | N/A |

| | | | | |
|--|--------------------------------|-----------------------|-----------------------|-----|
| 5. Fire Extinguisher: | | | | |
| A | Total numbers | 04 nos. | 06 nos. | MR |
| B | Types | CO ₂ & ABC | CO ₂ & ABC | MR |
| C | ISI marking | ISI Marked | ISI Marked | MR |
| 6 First-Aid-Hose Reel: | | | | |
| A | Total numbers of each floor | 01 no. | 01 no. | MR |
| B | Length of hose reel hose | 30 mtrs. | 30 mtrs. | MR |
| C | Nozzle diameter | 05 mm | 05 mm | MR |
| 7 Automatic Fire Detection and Alarming System: | | | | |
| A | Type of detectors | N/A | N/A | N/A |
| B | Location of main panel | N/A | N/A | N/A |
| C | Location of repeater panel | N/A | N/A | N/A |
| D | Alternate source of power | N/A | N/A | N/A |
| E | Hooters | N/A | N/A | N/A |
| 8 | MOEFA: | N/A | N/A | N/A |
| 9 | Public Address System: | N/A | N/A | N/A |
| 10 Automatic Sprinkler System: | | | | |
| A | Basement | N/A | N/A | N/A |
| B | Upper floor | N/A | N/A | N/A |
| C | Sprinkler above false ceiling | N/A | N/A | N/A |
| 11 Internal Hydrants: | | | | |
| A | Size of riser/down-comer | N/A | N/A | N/A |
| B | Number of hydrants per floor | N/A | N/A | N/A |
| C | Hose box | N/A | N/A | N/A |
| 12 Yard Hydrants: | | | | |
| A | Total number of hydrants | N/A | N/A | N/A |
| B | Hose box | N/A | N/A | N/A |
| 13 Pumping Arrangements: | | | | |
| 1 Ground level | | | | |
| A | Discharge of main pump | N/A | N/A | N/A |
| B | Head of main pump | N/A | N/A | N/A |
| C | Number of main pumps | N/A | N/A | N/A |
| D | Jockey pump out put | N/A | N/A | N/A |
| E | Jockey pump head | N/A | N/A | N/A |
| F | Standby pump out put | N/A | N/A | N/A |
| G | Standby pump head | N/A | N/A | N/A |
| H | Auto starting /manual stopping | N/A | N/A | N/A |
| I | Pump house access | N/A | N/A | N/A |
| 2 Terrace Level | | | | |
| A | Discharge of pump | 220 LPM | 220 LPM | MR |
| B | Head of the pump | 40 mtrs. | 40 mtrs. | MR |
| C | Power supply | Required | Provided | MR |
| D | Auto starting of pump | Required | Provided | MR |

| | | | | |
|-----------|---|------------------------------|-------------|-------------|
| 14 | Captive Water Storage for Fire Fighting: | | | |
| | A | Underground tank capacity | N/A | N/A |
| | B | Draw-off connection | N/A | N/A |
| | C | Fire service inlet | N/A | N/A |
| | D | Access to tank | N/A | N/A |
| | E | 'Overhead tank capacity | 2500 liters | 2500 liters |
| 15 | Exit Signage: | | | |
| 16 | Provision of Lifts: | | | |
| | A | Pressurization of lift shaft | N/A | N/A |
| | B | Pressurization of lift lobby | N/A | N/A |
| | C | Communication in lift car | N/A | N/A |
| | D | Firemen's grounding switch | N/A | N/A |
| | E | Lift signage | N/A | N/A |
| 17 | Standby Power Supply: | | | |
| 18 | Refuge Area: | | | |
| | A | Total area | N/A | N/A |
| | B | Location | N/A | N/A |
| 19 | Fire Control Room: | | | |
| | A | Detector system panel | N/A | N/A |
| | B | Flow switch panel | N/A | N/A |
| | C | PA system panel | N/A | N/A |
| | D | Battery backup | N/A | N/A |
| | E | Building floor plans | N/A | N/A |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | | | |

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the Rules the Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2022/NDZ/123 dated 07/02/2022 under the Circular No. 262 - 362 dated 17/01/2005 is recommended.

No file is pending with me before disposal of this case.


15/5/2025


Signature of the Inspecting Officer
Name Yashwant Singh Meena
Designation ADO (L.N)

~~DO/ED~~


15/5/2025


15/5/2025


15/5/2025


16/5/2025


17/5/25


17/5/25