



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6 /DFS/MS/Institute/SZ/2025/ 399

Dated: 20/08/2025

To,  
The Owner/Occupier/Manager,  
All India Asian Educational Foundation,  
Plot no-3 & 4, Josola, Sarita vihar,  
New Delhi-110025.

**Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s All India Asian Educational Foundation located at Plot no-3 & 4, Josola, Sarita vihar, New Delhi-110025.**

Sir,

With reference to the letter berating outdoor diary no. 1237 dated 11.05.2025 on the subject cited above, it is informed that the said building was inspected by officer concerned of this department on 13.05.2025 & 04.08.2025 in the presence of Mr. Sumit Kumar Singh and following shortcomings were observed:

1. Fire check door (FCD) found removed at some floors.
2. Horizontal and vertical openings found unsealed.
3. Smoke Management System not functional at upper floors.
4. Manual Operated Electrical Fire Alarm System (MOEFA) non functional in some area.

**In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected.** The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Virendra Singh)  
Chief Fire Officer  


**Copy to:-**

1. The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi-24.