




C-312



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/ECN/2026/ 122

Dated 25/06/2026

FIRE SAFETY CERTIFICATE

Certified that Allahabad Bank Building located at 17, Parliament Street, New Delhi - 110001, comprised of Basement, Ground and 04 Upper Floors. The premises was inspected by the officers concerned of this department on 20/05/2026 in the presence of Sh. Ashok Kumar, Chief Manager and found that the said building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class - Business Building with effect from 25/06/2026 for period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 25/06/2026 at New Delhi by.

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to :-

01C68

1. The Chairman, NDMC, Palika Kendra, New Delhi - 110001.
2. The Chief Manager, Allahabad Bank Building, 17, Parliament Street, New Delhi - 110001.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1.	Name & address of the building	Allahabad Bank Building, 17, Parliament Street, New Delhi.		
2.	Type of occupancy	Business Building Basement + Ground + 04 Upper Floors		
3.	Type of case	New		
4.	Details of previous FSC No.	N/A		
5.	Fire safety directives No.-	N/A		
6.	Date of inspection: -	20/05/2026		
7.	Name of the inspecting officer: -	Sh. Manish Kumar, DO(CD) Sh. Bhupender Prakash, ADO(CC)		
8.	Name & designation of officer From the building side: -	Sh. Ashok Kumar, Chief Manager		
9.	Year of construction: -	1994		
10.	Applicant's letter No: -	DFS Online Portal ID: - 52026051102836 dated 11.05.2026		
S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site	Remarks MR/NMR
1.	Access to Building			
	• Road width	9.00 mtr.	18.00 mtr.	MR'
	• Gate width	5.00 mtr.	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper floors	02 nos.	02 nos.	MR
	• Basements	02 nos.	05 nos.	MR
	b. Width of staircase			
	• Upper floors	1.25 mtr.	1.43 & 1.80 mtr.	MR
	• Basements	1.25 mtr.	1.43, 1.80, 1.30, 1.00 & 1.10 mtr.	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	01 no.	02 nos.	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.00 mtr.	1.00 mtr.	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided Natural	MR
5.	Fire Extinguishers			
	• Total numbers	50 nos.	55 nos.	MR
	• Types	ABC & CO ₂	ABC, CO ₂ & W.CO ₂	MR
	• ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	• Total number of each floor	03 nos.	03 nos.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	6 mm	6 mm	MR

7.	Automatic Fire Detection & Alarming System.			
	• Type of detectors	Smoke/Heat	Provided	MR
	• Location of main panel	Ground Floor	Provided	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper floors	N/A	Provided	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	150 mm	MR
	• Number of hydrants per floor	02 nos.	02 nos.	MR
	• Hose box per floor	02 nos.	02 nos.	MR
12.	Yard Hydrants			
	• Total number of hydrants	02 nos.	02 nos.	MR
	• Hose box	02 nos.	02 nos.	MR
13.	Pumping Arrangement			
	Ground level			
	• Discharge of main pump	1620 LPM	2280 LPM	MR
	• Head of main pump	70 mtr	70 mtr	MR
	• Number of main pumps	01 no.	01 no.	MR
	• Jockey pump out put	180 LPM	180 LPM	MR
	• Jockey pump head	70 mtr	70 mtr	MR
	• Stand by pump output	1620 LPM	2280 LPM	MR
	• Stand by pump head	70 mtr.	70 mtr.	MR
	• Auto starting/Manual stopping	Required	Provided	MR
	Terrace level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	2,00,000 Ltrs	2,00,000 Ltrs	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	10,000 Ltrs	10,000 Ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Fireman's switch	Required	Provided	MR
	• Lift signage	Required	Provided	MR

		Required	Provided	MR
17.	Stand by Power Supply			
18.	Refuge Area			
	• Total Area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector system panel	Required	Provided	MR
	• Flow switch panel	Required	Provided	MR
	• PA system panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any:			MR

'PNF' - Provided but Non-Functional, 'MR' - Meeting Requirement, 'NMR' - Not Meeting Requirement

The fire protection system provided in the building were randomly checked and found functional at the time of inspection. Further, the shortcomings issued vide this office letter No. F.6/DFS/MS/NDZ/2025/629 dated 22/12/2025 found complied.


Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, it is recommended to issue the FSC under Rule 33 of Delhi Fire Service Rules, 2010.

Accordingly, DFA is prepared and put up for perusal, approval and signature please.


10/6/26
Manish Kumar
DO (CD)


10/6/2026
Bhupender Prakash
ADO (CC)

CFO 
17/6/26


17/6/26

Principal Director

CFO to 


18/6/26
CFO (ECN)


19/6/26

As approved F.T. letter is put up for Signature please.
ADD/N.D.


22/6/2026

CFO (ECN)


23/6/26

MS