



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/Industrial/WZ/2025/ 286

Dated: 16/06/2025

To,

Mr. Ashutosh Goel (Director),  
M/s Allied Engineering Works Ltd.  
M-11 and M-22,  
Badli Industrial Estate,  
Delhi-110042,

**Sub:** Issue of FSC in r/o M/s Allied Engineering Works Ltd. at M-11 and M-22, Badli Industrial Estate, Delhi-110042.

Sir,

Kindly refer to letter received in this department through outdoor diary no. 1620 dated 14.05.2025 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **02.06.2025**, in presence of **Mr. Arun Kumar (GM)** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed

1. The width of Staircase is 1.20 mtr against the required width of 1.50 mtr & alternate staircase are not provide.
2. Both the staircases are not continues up to terrace floor.
3. Fire check door are not provided.
4. Hose reel provided but not functional.
5. Automatic sprinkler system is not provided in entire building.
6. Smoke management system not provided in basement.
7. Terrace fire pump provided is less than 900lpm capacity.
8. Underground tank capacity of 1, 00,000 ltrs not provided.
9. 10,000 ltrs Over Head water captive tank provided against the required capacity of 25,000 ltrs.
10. not provided
11. 02 different premises M-22 & M-11 are amalgamated together.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully

  
(Atul Garg)  
DIRECTOR  
Ph; 011-23414000

