



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/School/NDZ/2025/ 484

Dated: 06/06/2025

To,

The Principal,
Aman Bharti Modern School,
B-171-172, Main Nala wala road,
New Ashok Nagar, Delhi-110096.

Subject: - Regarding grant of Fire Safety Certificate in r/o Aman Bharti Modern School located at B-171-172, Main Nala wala road, New Ashok Nagar, Delhi-110096.

Sir,

This has a reference to your Outdoor diary No. 1426 dated 07/05/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 26/05/2025 in the presence of Principal and observed that building comprised of Ground plus three upper floors.

Following shortcomings were observed during time of inspection:

1. First-Aid-Hose Reel provided but not functional.
2. Fire pump of 220 LPM provided but found not functional.
3. Exit & floors Signage's found removed in strategic location in the building.
4. 2 SPS rooms on terrace shall be removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


5/6/2025

VIRENDRA SINGH
CHIEF FIRE OFFICER
o/c DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, MCD, Civic Centre, Jawahar Lal Nehru Marg, New Delhi - 110002.