



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-53

75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2026/535

Dated: - 02/06/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Aman Imperial Guest House, 3736 to 3737, Dariba Pan, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026050706483 dated 07/05/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 18/05/2026 in the presence of Sh. Suresh Kumar, Manager and following shortcomings were observed: -

1. Automatic operation of Fire pump found removed.
2. Domestic connection provided in Overhead Water storage tank is not permissible.

Keeping in view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands rejected. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,


(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

01c B8

Copy to: -

1. The Manager, M/s Aman Imperial Guest House, 3736 to 3737, Dariba Pan, Paharganj, New Delhi - 110055.