

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**


No.F6/DFS/MS/GH/NDZ/2026/ 69

Dated : 23/01/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s **Amar International Guest House**, located at **2024/7, Chuna Mandi, Paharganj, New Delhi** building comprised of Ground, plus Four Upper Floors, using Ground Floor as Reception, 1st, 2nd & 3rd Floors each having 07 Guest Rooms respectively and 4th Floor – Not in use (as per undertaking dated 14.01.2026) Total 21 Guest Rooms up to 3rd Floor only, owned/occupied by Amar International Guest House was issued FSC by this department vide letter No.F6/DFS/MS/GH/NDZ/2023/03 dated 02/01/2023. The guest house was re-inspected by the officer concerned of this department on **15/01/26** in the presence of **Sh. Shantanu, General Manager** and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **“Residential building, (Sub Division – A-1): (Guest House) for Ground Floor (Reception), 1st Floor (07 Guest Rooms), 2nd Floor (07 Guest Rooms) and 3rd Floor (07 guest rooms) Total 21 guest rooms up to third floor only** with effect from **23/01/2026** for period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued ... 23/01/2026 at New Delhi by.


23/01/2026

(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

01/08/2026

Copy To: -

1. The Commissioner, Municipal Corporation of Delhi, Civic Centre, Minto Road, New Delhi w.r.t Online application ID No. 2025122916208 dated 29/12/2025.
2. The Manager, M/s Amar International Guest House, located at 2024/7, Chuna Mandi, Paharganj, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. This FSC is valid for Guest House up to third floor only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
4. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
5. The trained firefighting staff should be available round the clock.
6. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
10. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1.	Name & address of the building: -	M/s Amar International Guest House, 2024/7, Chuna Mandi, Paharganj, New Delhi.		
2.	Type of occupancy: -	Residential, "Group-A" (Guest House) Ground + 04 Upper Floors (Guest House running at Ground Floor – Reception, 1 st Floor 07 guest rooms, 2 nd Floor 07 guest rooms, 3 rd Floor 07 guest rooms – Total 21 Guest Rooms) 4 th Floor – Not in use (an affidavit dated 14.01.2026 regarding not to use any floor above third floor, submitted by owner.)		
3.	Building Comprised of: -			
4.	Type of case: -	Renewal		
5.	Details of previous FSC: -	No.F6/DFS/MS/GH/NDZ/2023/03 dt. 02/01/2023		
6.	Fire safety directives No.: -	N/A		
7.	Date of inspection: -	15/01/2026		
8.	Name of the inspecting officer: -	Sh. Bhupender Prakash, ADO(CC)		
9.	Name & designation of officer From the building side: -	Sh. Shantanu, General Manager		
10.	Year of construction: -	1990		
11.	Applicant's letter No: -	MCD Online ID. 2025122916208 dated 29/12/2025		
S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	• Road width	N/A	06 mtr.	N/A
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper floors	01 no.	01 no.	MR*
	• Basements	N/A	N/A	N/A
	b. Width of staircase			
	• Upper floors	0.80 mtr.	1.17 mtr.	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check dcor	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.00 mtr.	1.00 mtr.	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Provided Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	08 nos.	10 nos.	MR
	• Types	ABC & CO ₂	ABC & CO ₂	MR
	• ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	• Total number of each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR

7.	Automatic Fire Detection & Alarming System.			
	• Type of detectors	Required	Provided	MR
	• Location of main panel	Ground Floor	Provided	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's Location	At each floor	Provided	MR
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	Ground level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Stand by pump output	N/A	N/A	N/A
	• Stand by pump head	N/A	N/A	N/A
	• Auto starting/Manual stopping	N/A	N/A	N/A
	• Pump House Access	N/A	N/A	N/A
	Terrace level			
	• Discharge of pump	225 LPM	225 LPM	MR
	• Head of pump	30 mtr.	30 mtr.	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	2,500 ltr.	2,500 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Fireman's switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A

	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:	N/A	N/A	N/A

*PNF – Provided but Non-Functional, *MR – Meeting Requirement, *NMR – Not Meeting Requirement

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. F6/DFS/MS/GH/NDZ/2023/03 dt. 02/01/2023 up to third floor only under rule 35(6) of the Delhi Fire Service rules 2010. The last date for deemed approval is **27/01/2026**.

Accordingly, DFA is prepared and put up for perusal and signature please.

Bhupender Prakash
Bhupender Prakash
ADO (CC)

DO (CD) *16/01/26*

Dy. CFO (N/2) *16/01/26*

Principal Director

Dy. CFO (N/2)

Dy. CFO to Gen.

16/01/26

Dy. CFO
21/1/26

ADO/CC

As approved F.T. letter is put for signature please.

Bhupender Prakash
27/01/2026

Dy. CFO (N/2)

23/1/26

ms
Amar International Guest House, 2024-7, Chuna Mandi, Paharganj, New Delhi

uploaded
23/1/26