



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/School/NDZ/2025/177

Dated: 26/03/2025

To,

The Principal,
Amar Jeevan Public School
F – 190, Laxmi Nagar,
Delhi – 110092.

Subject: - Regarding grant of Fire Safety Certificate in r/o Amar Jeevan Public School located at F – 190, Laxmi Nagar, Delhi – 110092.

Sir,

This has a reference to your Outdoor diary No. 13040 dated 28/02/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 18/03/2025 in the presence of Mr. Sanjay Kumar (Principal) and observed that building comprised of ground plus three upper floors.

Following shortcomings were observed during time of inspection:

1. Second staircase found removed. One fire escape of width 0.75 m is required to be provided from Ground to upper floors.
2. First-Aid-Hose Reel found removed.
3. Fire pump of 220 LPM found removed.
4. Over head water storage tank of capacity 5,000 liters found removed.
5. Exit & floors Signage's found removed at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi - 110053.