




e 9



GOVERNMENT OF NATIONAL CAPITAL TERRITORY (OF DELHI)  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F.6/DFS/MS/School/2025/NDZ/ 1058

Dated: 25/08/2025

**FIRE SAFETY CERTIFICATE**

Certified that Amar Jeevan Public School located at New Govindpura, Delhi-110051, comprised of Basement, Ground plus three upper floors, owned/occupied Amar Jeevan Public School was issued FSC vide letter No. F.6/DFS/MS/School/2008/1793 dated 27/06/2008. The premises was re-inspected by the officers concerned of this department on dated 08/08/2025 in the presence of Sh. Chander Prakash Aneja (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. 262-362 dated 17/01/2005 issued by the Director of Education and that **the building/premises is fit for occupancy class 'Educational (Group-B)'** with effect from ...25/08/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on .....25/08/2025..... at New Delhi by

25/08/2025

(VIRENDRA SINGH)

o/c CHIEF FIRE OFFICER

To,

1. The Manager, Amar Jeevan Public School located at New Govindpura, Delhi-110051
2. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry
8. Basement shall be used as per NBC part-IV

N/7

1. Name & address of the building : Amar Jeevan Public School,  
New Govindpura, Delhi-110051
2. Building is comprised of : Basement, Ground plus three upper floors  
(Basement use for storage only)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2008/1793 dated 27/06/2008
6. Fire Safety direction letter No : Circular 262-362 dated 17/01/2005 issued by DoE
7. Date of Inspection : 08/08/2025
8. Name of the Inspecting officers : Deepak Kumar, ADO (Shahdara)
9. Name and designation of Officer  
from the building side : Sh. Chander Prakash Aneja (Manager)
10. Year of Construction : 2000
11. Applicant's letter No : 04/07/2025 dated 04/07/2025

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular 17/01/2005 Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	06 mtr.	09mtr.	MR
	• Gate width	N/A	N/A	MR
	• Width of internal road	N/A	N/A	MR
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	01 no	02no.	MR
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper floor	1.50 mtr./ 0.75 mtr	1.15mtr, 0.78mtr & 0.85mtr- ground to first	MR
	• Basement	01 mtr	01 mtr	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 No.	01 No.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers.			
	• Total numbers	06nos.	06nos.	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR




06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 no.	01 no	MR
	• Length of hose reel hose	30 mtr	02 no	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 nos.	01 nos.	MR
	• Hose box	01 nos.	01 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 LPM	450 LPM	MR
	• Head of the pump	40 mtr	40 mtr	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	5,000Ltr	6,000Ltr	MR
15	Exit Signage.	Required	Provided	MR




p/a.




16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

The fire protection system provided in the building were tested/checked and found functional at the time of inspection.


Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule. The FSC issued vide letter no. F.6/DFS/MS/School/2008/1793 dated 27/06/2008 **renewal under rule 35 of the Delhi Fire Service Rules, 2010, is recommended.**

  
 Signature of the inspection Office  
 Name :- Deepak Kumar  
 Designation :- A.D.O (Shahdara)

~~DO/ED~~  11/08/2025  
 By C.F.O. (K.B.2)  11/08/2025  
 C.F.O.  16/8/2025  
 Principal Director

 to Secy.  
  
 18/08/2025  
 C.F.O.   
 A.D.O (Shahdara) 

Sir,  
 F.T. letter is put up for your kind  
 signature pl.

C.F.O. 

  
 21/08/2025

MS