




No. F6/DFS/MS/School/NDZ/2025/951

Dated: 06/08/2025

FIRE SAFETY CERTIFICATE

Certified that the **Amar Jeevan Public School** located at **F – 190, Laxmi Nagar, Delhi – 110092**, building comprised of ground plus three upper floors, but school running on ground plus two upper floors only, third floor closed by owner, owned/occupied by **Amar Jeevan Public School** was issued FSC vide letter No. F6/MS/DFS/2006/1499 dated 06/07/2006. The school building was re-inspected by the officer concerned of this department on 21/07/2025 in presence of Mr. Sanjay Kumar Aneja (Manager) and found that school building have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular No. 262 - 362 dated 17/01/2005 issued by Director of Education and the building premises is fit for occupancy of class “Educational Building” (Group “B”) for ground plus two upper floor only with effect from 06/08/2025 for a period of **three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 06/08/2025 at New Delhi by.


VIRENDRA SINGH
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Dy. Director of Education, D - Block, Anand Vihar, Delhi - 110092.
2. The Manager, Amar Jeevan Public School located at F – 190, Laxmi Nagar, Delhi – 110092.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form ‘K’ provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. At the time of inspection third floor closed by owner.
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner / occupier shall apply for renewal of this fire safety certificate to the Director in form J’ [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

R/09

INSPECTION REPORT

1	Name & address of the building	Amar Jeevan Public School located at F – 190, Laxmi Nagar, Delhi – 110092.		
2	Building is comprised of	Ground plus three upper floors, but school running on ground plus two upper floor only, third floor closed by owner.		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal Case		
5	Details of previous FSC	F6/MS/DFS/2006/1499 dated 06/07/2006		
6	Fire safety directives letter no.	DOE Circular No. 262 - 362 dated 17/01/2005		
7	Date of inspection	21/07/2025		
8	Name of the inspecting officers	Yashwant Singh Meena, ADO/Laxmi Nagar		
9	Name of the designation of officer from the building side	Mr. Sanjay Kumar Aneja (Principal)		
10	Year of construction	--		
11	Applicant's letter no.	Outdoor diary No. 3642 dated 11/07/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Old Circular requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	6.0 mtrs.	6.0 mtrs.	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	02 no.	02 no.	MR
	b Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.50 mtrs.	1.10 mtr. & 0.65 mtr. (upto 2 st floor only)	MR
	b Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	01 no	01 no	MR
	E Width of corridor	N/A	N/A	N/A
	F Door size	1.0 mtr.	1.0 mtr.	MR
3	Compartmentation:			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A

H/10

5.	Fire Extinguisher:				
	A	Total numbers	06 nos.	06 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI Marked	ISI Marked	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	01 no	01 no	MR
	B	Length of hose reel hose	30 m	30 m	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:				
			N/A	N/A	N/A
9	Public Address System:				
			N/A	N/A	N/A
10	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	220 LPM	220 LPM	MR
	B	Head of the pump	40 m	40 m	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

3

14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	N/A	N/A
	B	Draw-off connection	N/A	N/A
	C	Fire service inlet	N/A	N/A
	D	Access to tank	N/A	N/A
	E	Overhead tank capacity	5,000 liters	Provided
15	Exit Signage:		Required	Provided
16	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	N/A	N/A
17	Standby Power Supply:		N/A	N/A
18	Refuge Area:			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19	Fire Control Room:			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:		N/A	N/A

Note: - At the time of inspection that the building comprised of ground plus three upper floors, but school running on ground plus two upper floors only, third floor closed by owner (Undertaking enclosed C-18).

The fire protection system was randomly checked and tested and was found functional at the time of inspection. The earlier shortcomings issued vide letter no. F6/DFS/MS/School/2025/177 dated 26/03/2025 by this department has been rectified by the management.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of FSC issued vide letter no. F6/MS/DFS/2006/1499 dated 06/07/2006, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer
Name Yashwant Singh Meena
Designation ADO/Laxmi Nagar

D.O/EAST

DFA fl.
22/7/2025

Dy CPO (R&Z)

C.F.O.
28/7/2025

Principal Director

ADOKar
P.T.O.

23/07/25

CFO to Issu.

28/07/25