



## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE NEW DELHI- 110 001

No.F.6/DFS/MS/School/2025/NDZ/ 335

Dated: 03 04 2025

## FIRE SAFETY CERTIFICATE

Certified that the Amar Jyoti School located at Karkardooma, Vikas Marg, Delhi-110092, comprised of ground plus two upper floor, owned/occupied by Amar Jyoti Charitable Trust has already been issued FSC vide letter no. F.6/DFS/MS/School/2022/NDZ/554 dated 20/05/2022. The premises was re-inspected by the team of officer of this department on 22/03/2025 in the presence of Mr. Kamal Pandey and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class 'Educational (Group-B)' with effect from 63.04.2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on .....03 04 2025. at New Delhi by

(ATUL GARG) DIRECTOR ELHI FIRE SERVIC

To,

Dr. (Mrs.) Uma Tuli (Founder & Managing Secretary), Amar Jyoti School at Karkardooma, Vikas Marg, Delhi-110092

Copy:-

The Director of Education, Old Secretariat, Civil Lines, Delhi- 110054

## Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.

2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.

3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.

4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.

5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.

6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on <a href="www.dfs.delhigovt.nic.in">www.dfs.delhigovt.nic.in</a>

7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

1. Name & address of the building

2. Building is comprised of

3. Type of Occupancy

4. Type of Case

5. Details of Previous NOC letter

6. Fire Safety directive letter No.

7. Date of Inspection

8. Name of the Inspecting officers

9. Name and designation of Officer from the building side

10. Year of Construction

: Amar Jyoti School

Karkardooma, Vikas Marg, Delhi-110092

:Ground plus two upper floors

:Educational

:Renewal

: F.6/DFS/MS/School/2022/NDZ/554 dt 20/05/2022

:NBC Part IV

:22/03/2025

: DO, A.K Jaiswal & ADO (Shd.) Deepak Kumar

: Mr. Kamal Pandey

:2008

outdoor diary no. 12859 dated 24/02/2025

	11. Applicant's letter No	NBC Part-IV	Provided at Site	Remarks MR/NMR				
Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Requirement	stra Sasta	IVII OT COM				
01	Access to Building							
		06mtr.	20 mtr.	NA C				
	Road width	4.50 mtr	4.50 mtr	N/A				
	Gate width	N/A	N/A	14//				
	Width of internal road							
02	Width of Internal road     Number, Width, Type and Arrangement of Exits							
	a. Number of Staircases		One stair & one	MR				
	Upper floor	02nos	ramp	7 7				
	• Opper noon		N/A	N/A				
	Basement	N/A						
			3	MR				
	B. Width of Staircases	1.50 mtr	1.25 mtr &	IAIT				
	Upper floor	_	1.42mtr ramp					
			N/A	N/A				
	Basement	N/A	14/74					
	c. Protection of Exits	51/A	N/A	N/A				
	Fire check door	N/A	N/A	N/A				
	Pressurization	N/A	01 no.	MR				
	d. No. of Continuous Staircases	01 no.	- THE THE					
	to Terrace	1.50 mtr.	1.50 mtr	MR				
	e. Width of Corridor	N. III	01 mtr	MR				
		01mtr.	OT mu					
	f. Door Size							
03	Compartmentation.							
	Fire check door	N/A	N/A	N/A				
	Sealing of electrical shafts	N/A	N/A	N/A				
	Fire rating of shaft door	N/A	N/A	N/A				
	Water curtain	N/A	N/A	N/A				
	Fire dampers	N/A	N/A	N/A				
04	Smoke Management System.							
	Basement	N/A	N/A	N/A				
05.		N/A	N/A	N/A				
	• Upper floor Fire Extinguishers							
	The Macour and Administration of the Saksa Centre	08nos	MR					
	Total numbers     Types	08nos.						
	• Types	ABC /CO <sub>2</sub>	ABC & CO₂	MR				
	IS marking	ISI marked	Provided	MR				

Special and special control of the special control of

+	Total numbers on each floor	01 nos	01 nos	MR
	Length of hose reel hose	30 mtr	30 mtr	MR
	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarming Sy		33 11111	IVII
+	Type of detectors	N/A	N/A	N/A
-	Location of main panel	N/A	N/A	N/A
- 1	Location of repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	Hooter	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	Basement	N/A	N/A	N/A
	upper floor	N/A	N/A	N/A
i dis	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants	1371		
	size of riser/down-comer	N/A	100 mm	N/A
	Number of hydrants per floor	N/A	01 no.	N/A
	Hose box	N/A	01 no.	N/A
12	Yard Hydrants.		0 W	
	Total number of hydrants	N/A	N/A	N/A
	Hose box	N/A	N/A	N/A
13	Pumping Arrangements.	AC	Street, J.	
	> Ground Level		year made a	1
ASS	Discharge of main pump	N/A	N/A	N/A
	Head of main pump	N/A	N/A	N/A
	Number of main pumps	N/A	N/A	N/A
2.00	Jockey pump out put	N/A	N/A	N/A
1	Jockey pump head	N/A	N/A	N/A
65	Standby pump out put	N/A	N/A	N/A
	Standby pump head	N/A	N/A	N/A
531	- Mato otarting manage exeppg	N/A	N/A	N/A N/A
-	Pump house access     Terrace Level	N/A	N/A	N/A
	ACC Management (Autority Charles)	AEO Inco	450 lpm	MR
	Discharge of pump	450 lpm 40 M	450 Ipm 40 M	MR
	Head of the pump		Provided	MR
		Required		1411
	Power supply	Required Required	Provided	MR
44	Power supply     Auto starting of pump		14 14 4 15 15 15 15 15 15 15 15 15 15 15 15 15	MR
14	Power supply     Auto starting of pump		14 14 4 15 15 15 15 15 15 15 15 15 15 15 15 15	MR
14	Power supply     Auto starting of pump  Captive Water Storage for Fire	Required N/A	Provided N/A	N/A
14	Power supply     Auto starting of pump  Captive Water Storage for Fire Fighting.	Required  N/A  N/A	N/A N/A	N/A N/A
14	Power supply     Auto starting of pump  Captive Water Storage for Fire Fighting.  Underground tank capacity	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
14	Power supply     Auto starting of pump  Captive Water Storage for Fire Fighting.      Underground tank capacity     Draw-off connection     Fire service inlet	N/A N/A N/A N/A N/A	N/A N/A N/A N/A	N/A N/A N/A
	Power supply     Auto starting of pump  Captive Water Storage for Fire Fighting.  Underground tank capacity     Draw-off connection     Fire service inlet	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A

2



16	Provision of Lifts.					
	Pressurization of lift shaft	N/A	N/A	N/A		
	<ul> <li>Pressurization of lift lobby</li> <li>Communication in lift car</li> </ul>	N/A	N/A	N/A		
		N/A	N/A	N/A		
	<ul> <li>Firemen's grounding switch</li> </ul>	N/A	N/A	N/A		
	<ul> <li>Lift signage</li> </ul>	N/A	N/A	N/A		
17	Standby Power Supply	N/A	N/A	N/A		
18	Refuge Area.					
	Total area	N/A	N/A	N/A		
	Location	N/A	N/A	N/A		
19	Fire Control Room					
	Detector system panel	N/A	N/A	N/A		
	그는 하시스트 생겨장 느 그림 주내고 말했다고 그렇게 느	N/A	N/A	N/A		
	Flow switch panel	N/A	N/A	N/A		
	PA system panel	N/A	N/A	N/A		
	Battery backup	N/A	N/A	N/A		
00	Building floor plans     Supplementary	N/A	N/A	N/A		
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	13073	190188 T			

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no. F.6/DFS/MS/School/2022/NDZ/554 dated 20/05/2022 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

Signature of the Inspecting Officer

Name

:- Deepak Kumar

Designation

:- A.D.O (Shd)

Any SM Siz FT. lyker is but 4p for yours Dupour