



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5
आशादीन
अमृत महोत्सव

No. F6/DFS/MS/BNQT/NDZ/2025/ 71

Dated: 30/04/2025

To

The Joint Commissioner of Police,
Office of Joint Commissioner of Police: Licensing,
1st Floor, P. S Defence Colony, New Delhi.

Sub: -Regarding renewal of Fire Safety Certificate in r/o M/s Amar Palace Banquet Hall located at 512, Jheel Khuranja, Geeta Colony Chowk, Delhi-51.

Sir,

With reference to the etl.mcdonline application ID no. 2025031703702 on the subject cited above, it is informed that the said Banquet hall was inspected officer concerned from this department on 22.04.2025 in the presence of Mr. Parminder Singh (Owner) and it was observed that the Banquet hall running at Ground + 01 upper floor in a building comprised of Ground + 1st floor + 2nd floor (SPS/Temporary structure). During the inspection following shortcomings were observed

1. Alternate exit at ground floor has not been provided.
2. Both staircases not upto the terrace/2nd floor.
3. Manual Operated Electrical Fire Alarm (MOEFA) system found non functional.
4. All water based systems like Hose reels, Downcomer, Fire Pump are non functional.
5. Overhead fire tank capacity of 15,000 liters has not been provided.
6. Access to terrace tank & fire pump has not been provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, Dr. SPM Civic Centre, JLN Marg, New Delhi.
2. The Deputy Health Officer, Health Department, MCD, Shahdara (South Zone), Delhi.