

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/GH/NDZ/2025/173

Dated: 17/10/2025

To

The Commissioner,  
Municipal Corporation of Delhi,  
Dr. SPM Civic Centre, New Delhi - 02.

Sub: Regarding renewal of Fire Safety Certificate (FSC) in r/o M/s Amar Palace located at  
Prop. No. 512, Jheel Khureja, Shahdara, Delhi - 110051.



Sir,

This has reference to MCD portal online application Id No.2025091213392 dated 12.09.2025 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on dated 27.09.2025 in presence of Mr. Parminder Singh (Owner) and observed that the shortcomings intimated vide letter of even No.F6/DFS/MS/BNQT/NDZ/2025/71 dated 30/04/2025 (copy enclosed) have not been complied yet.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building /premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

Encl: As above.

  
(Dr. S. K. Tomar)  
Dy. Chief Fire Officer  
Delhi Fire Service  


**Copy to:-**

The Licensee,  
M/s Amar Palace located at Prop. No. 512, Jheel Khureja, Shahdara, Delhi - 110051.



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

4/80

DFA+PR  
75  
आजादी का  
अमृत महोत्सव

No. F6/DFS/MS/BNQT/NDZ/2025/ 71

Dated: 30/04/2025

To

The Joint Commissioner of Police,  
Office of Joint Commissioner of Police: Licensing,  
1<sup>st</sup> Floor, P. S Defence Colony, New Delhi.

**Sub: -Regarding renewal of Fire Safety Certificate in r/o M/s Amar Palace Banquet Hall located at 512, Jheel Khuranja, Geeta Colony Chowk, Delhi-51.**

Sir,

With reference to the etl.mcdonline application ID no. 2025031703702 on the subject cited above, it is informed that the said Banquet hall was inspected officer concerned from this department on 22.04.2025 in the presence of Mr. Parminder Singh (Owner) and it was observed that the Banquet hall running at Ground + 01 upper floor in a building comprised of Ground + 1<sup>st</sup> floor + 2<sup>nd</sup> floor (SPS/Temporary structure). During the inspection following shortcomings were observed

1. Alternate exit at ground floor has not been provided.
2. Both staircases not upto the terrace/2<sup>nd</sup> floor.
3. Manual Operated Electrical Fire Alarm (MOEFA) system found non functional.
4. All water based systems like Hose reels, Downcomer, Fire Pump are non functional.
5. Overhead fire tank capacity of 15,000 liters has not been provided.
6. Access to terrace tank & fire pump has not been provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Arun Garg)  
Director  
Delhi Fire Service

**Copy to:-**

1. The Commissioner, MCD, Dr. SPM Civic Centre, JLN Marg, New Delhi.
2. The Deputy Health Officer, Health Department, MCD, Shahdara (South Zone), Delhi.