



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-74



No. F6/DFS/MS/WZ/2026/ 504
To,

Dated: - 22/05/2026

The Commissioner,
Municipal Corporation of Delhi,
Dr. S.P.M. Civic Centre, JL Nehru Marg,
New Delhi -110002.

Sub.: Regarding renewal of Fire Safety Certificate in respect M/s. Amitabh Guest House, located E-23, Banglow Road, Kamla Nagar, Delhi-110007.

Sir,

This has reference to online application no. 2026033003868 dated 14/04/2026 on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officers concerned of this department on 08/05/2026 in the presence of Sh. Amitabh (Owner) to view the availability & operability of fire safety measures provided in the premises as per NBC-2005 and it was observed that the above said guest house is running at 1st floor only in a building comprised of basement + ground + 02 upper floors. After inspection, the following shortcoming were observed: -

1. Fire check door found removed.
2. Smoke Management System found removed.
3. CO type detector found removed.
4. First-aid hose reel found removed.
5. Internat hydrants found removed.
6. Overhead water storage tank of 20,000 ltrs. capacity found removed.
7. Exit signages found inadequate.

In view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage & **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


21/05/26

(S.K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Authorized Signatory, M/s. Amitabh Restaurant, located E-23, Ground Floor, Banglow Road, Kamla Nagar, Delhi-110007.

