



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/WZ/2026/503

Dated: - 22/05/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Dr. S.P.M. Civic Centre, JL Nehru Marg,
New Delhi -110002.

Sub.- Regarding renewal of Fire Safety Certificate in respect M/s. Amitabh Restaurant, located E-23, Ground Floor, Banglow Road, Kamla Nagar, Delhi-110007.

Sir,

This has reference to online application no. 2025121515738 dated 14/04/2026 on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officers concerned of this department on 28/04/2026 in the presence of Sh. Amitabh. During inspection, it was observed that the above said restaurant is running at ground floor only in a building comprised of basement + ground + 02 upper floors. After inspection, the following shortcoming were observed: -

1. Segregation of Eating House i.e. Ground to Guest House (1st floor) found removed.

In view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage & **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


21/05/26

(S.K. Dua)
Chief Fire Officer
Delhi Fire Service



Copy to: -

1. The Authorized Signatory, M/s. Amitabh Restaurant, located E-23, Ground Floor, Banglow Road, Kamla Nagar, Delhi-110007.