




**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**



No: F.6/DFS/MS/2025/WZ/ 441  
To,

Dated: 04/09/2025

Sh. R.P. Tyagi,  
Amrit Co-Op Group Housing Society Ltd.,  
Rashmi Apartments, Harsh Vihar,  
Pitampura, New Delhi- 110034.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Amrit Co-Op Group Housing Society Ltd. (Rashmi Apartments) located at Harsh Vihar, Pitampura Delhi- 110034.

Sir,

This has reference to your e mail id dated 05/08/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said residential building has been carried out by officer concerned of this department on 20.08.2025 to see the compliance of the requisite fire safety measures. Sh. Virender Kumar Arora (Treasurer) & Sh. Kuldeep Singh (Manager) were present at the time of inspection.

During the course of inspection it was observed that the building comprised of 07 Blocks (02- Blocks = Stilt + 7 upper floors each) & (05 Blocks = Ground + 3 upper floors each). Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. Internal road found blocked by private cars.
2. Fire check doors found removed.
3. P.A system found removed.
4. Hose boxes found without hose pipes.
5. Terrace level pump not found in auto mode.
6. Exit signage's found removed at some places.
7. P.A. system panel found removed.
8. Building floor plans found removed.
9. Balconies found covered by metal railings and plastic/ fiber sheets.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/ Occupier.

Yours Faithfully

  
31/8/25  
(Virendra Singh)  
Chief Fire Officer