



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-21



No. F6/DFS/MS/2025/School/ 848

Dated: 03/07/2025

FIRE SAFETY CERTIFICATE

Certified that the Amritodya Children's Academy running at Ground & First Floor only in a building comprised of Ground, First Floor (School), Second Floor (owner residence), Third Floor (owner residence) & fourth floor (sealed with brick wall) use as per affidavit dated 30/05/2025, located at Shiv Mandir Road, Swaroop Nagar, Delhi-110042, owned/ occupied by Amritodya Children's Academy, was issued Fire Safety Certificated by this department vide letter No. F6/DFS/MS/School/2018/WZ/1897 Dated 14/08/2018. The premises was re-inspected by the officer concerned of this department on 23/06/2025 in presence of Mr. Shubham (Manager) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "**Group B Educational (School) for ground & first floor only**" with effect from 03/07/2025 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on 03/07/2025 at New Delhi by.

(Atul Garg)
Director
Ph: 011-23414000

Copy to: -

1. The Deputy Director of Education, GNCT of Delhi, Zone-VII, District North Lucknow Road, Timarpur, Delhi - 110054.
2. The Manager, Amritodya Children's Academy located at Shiv Mandir Road, Swaroop Nagar, Delhi-110042.

Conditions for the validity of Fire Safety Certificate:

1. This Fire Safety Certificate is valid only for ground & first floor. If any violation in this regards, the Fire Safety Certificate will be treated as null & void.
2. All the means of escape shall be kept free from any type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
4. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
6. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
7. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".
9. The fourth floor is sealed by brick wall by the school management and 2nd & 3rd floor are in use for residential purpose with separate entry & exit. An undertaking with photographs has been submitted by the management of the building and if the building above 1st floor is used for school purpose, the FSC shall stand cancelled and shall be treated null and void.

INSPECTION REPORT

1. Name & address of the building : Amritodya Children's Academy at Shiv Mandir Road,
Swaroop Nagar, Delhi-110042.
2. Composition of building : Ground & 04 upper floors, But school is running at ground
& first floor only, 2nd & 3rd floor use for residence, 4th floor
Sealed by brick wall as per Affidavit dated 30/05/2025
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2018/WZ/1897 Dated 14/08/2018
6. Fire Safety directives letter No : Nil
7. Date of inspection : 23/06/2025
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
From the building side : Mr. Shubham (Manager)
10. Year of Construction : 2010 & 2016
11. Applicant's letter No. : Letter No. A.C.A/D.F.S Dated 30/05/2025

	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E Circular dated 01/03/2011 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	Directly accessible	Directly accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.50m & 1.10m	MR (being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	01	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	01m	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			

	<ul style="list-style-type: none"> Basements Upper floors 	NA	NA	NA
		Required	Natural Ventilation	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	05nos	Provided	MR
		ABC/Co2	Provided	MR
		Yes	Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	Captive Water Storage for fire fighting.			

