



C/52



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F.6/DFS/MS/GH/2025/SZ/ 54

Dated: 31/01/2025

To,
The Joint Commissioner (Lic.)
1st floor Police Station Defence Colony,
New Delhi

**Subject: -Regarding renewal of Fire Safety Certificate in r/o M/s Anand Lok Inn located at A-89,
Road No-4, Mahipal pur New Delhi-110037.**

Sir,

This is in reference to online portal ID.2024061709476 dated 10/01/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of the above mentioned guest house from fire safety point of view in presence of Mr. Pradeep Kumaron dated 22/01/2025. The building comprised of basement & ground plus four upper floor & two temporary rooms constructed at terrace. The following shortcomings were observed during the time of inspection.

1. The 4th floor shall not used for any purpose.
2. Two temporary rooms constructed at terrace running as Kitchen shall be demolished.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)

DIRECTOR

DELHI FIRE SERVICE

o/c L.

Copy to:-

Mr. Pradeep Kumar

M/s Anand Lok Inn (Guest House) A-89, Road No-4, Mahipal pur New Delhi-110037.