

C-188



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/BNQT/WZ/2026/292

Dated: 07/04/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Center, New Delhi – 110002.

Subject: - Regarding grant of Fire Safety Certificate in r/o Ananda Banquets, located at GF, FF & SF, Plot no. 33/33A, Shivaji Marg, Najafgarh Road, New Delhi-110015.

Sir,

This has a reference to MCD application No. 2026030602447 dated 08/03/2026, on the subject cited above. In this connection, this is to inform you that the above mentioned premises was visited by the officers concerned of this department on dated 28/03/2026 in the presence of Mr. Ishant Harjai (Owner) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observation :-

1. Fire Check doors found defective needs to be repaired/replaced.
2. Smoke management system provided but found not functional in basement.
3. Hose reel provided but found not functional.
4. Detectors and sprinkler needs to be extended in left out areas.
5. Sprinkler in basement found not functional.
6. Internal hydrant found not functional.
7. Fire pumps found not functional.
8. Underground water tank which is provided on terrace of capacity 50,000 lit. found empty.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(S.K. Dua)

Dy. Chief Fire Officer (WZ)