



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 514

Dated: 10 /06 /2025

To

The Manager,
Angel Dales Public School
Plot No. 2752, Near Robin Cinema,
old Sabzi Mandi, Delhi-07

Sub: Regarding issuance of fire safety certificate in r/o Angel Dales Public School located at Plot No. 2752, Main Bazar, Near Robin Cinema, old Sabzi Mandi, Delhi-110007.

Sir,

Please refer to your letter no. Nil dated 15/05/2025 received in this department vide outdoor dairy no. 1686 dated 15/05/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 02/06/2025 to verify the fire safety measures issued vide NBC Part-IV and observed that as per earlier NOC issued by this department letter of even no. F6/MS/DFS/2006/1716 dated 25/07/2006 the building was comprised of basement, ground & 02 upper floors only. The school management has added one more floor now the building is comprised of basement, ground & 03 upper floors. At the time of inspection Dr. A.D. Parchanda (Manager) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

- 1 There is 02 nos. of exits/staircases is provided in basement width of 80cm & 50cm against the requirement of 1.50m each/exits.
- 2 There is 02 nos. of staircases is provided width of 1.50m from ground to 3rd floor and one staircase 82cm from ground to terrace level against the requirement of 1.50m each from ground to terraces level.
- 3 Hose reel hose is provided but not functional.
- 4 Terrace level fire fighting pump capacity of 450 lpm found removed at site.
- 5 Terrace level fire water tank capacity of 10,000 ltrs found removed at site.
- 6 Exit signage found removed at strategic locations in the school building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(M.K. Chattopadhyay)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, 16 Rajpura Road, Delhi.