



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/1039

Dated: 21/08/2025

FIRE SAFETY CERTIFICATE

Certified that the Angel Dales Public School located at Plot No. 2752, Main Bazar, Near Robin Cinema, old Sabzi Mandi, Delhi-110007 comprised of basement, ground & 03 upper floors but school is running at basement, ground & first floor only owned/occupied by Angel Dales Public School was granted NOC by this department vide letter no. F6/MS/DFS/2006/1716 dated 25/07/2006. The premises was inspected by the officer concerned of this department on 06/08/2025 in presence of Dr. A.D. Parchanda (Manager) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 262-362 dated 17.01.2005 and the building/ premise is fit for occupancy class "Group B Educational (School)" for basement, ground & first floor only with effect from21/08/2025 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on21/08/2025..... at New Delhi by.

[Signature]
 21/08/2025
 Virendra Singh
 Chief Fire Officer
 Delhi Fire Service
[Signature]

Copy to :-

1. The Dy. Director, Education Department, Civil Line Zone, MCD, 16, Rajpura Road, Delhi.
2. The Manager, Angel Dales Public School located at Plot No. 2752, Main Bazar, Near Robin Cinema, old Sabzi Mandi, Delhi-110007.

Conditions for the validity of Fire Safety Certificate:

1. This Fire Safety Certificate is valid for ground floor & first floor and basement for storage purpose only. In case of any violation, this FSC will be treated as null & void.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Angel Dales Public School at Plot No. 2752, Main Bazar, Near Robin Cinema, Old Subzi Mandi, Delhi-110007.
2. Type of Occupancy : Educational (School)
3. Type of Case : Renewal
4. Composition of building : Basement, Ground & 03 upper floor, But school is running at ground & First floor, basement for storage, 2nd & 3rd floor are being used for Owner residence purpose
5. Details of previous NOC : F6/MS/DFS/2006/1716 dated 25/07/2006 (Basement, ground & first floor)
6. Fire Safety directives letter No : Nil
7. Date of inspection : 06/08/2025
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Dr. A. D. Parchanda (Manager)
10. Year of Construction : 1983 & 2014
11. Applicant's letter No. : Online e-mail dated 28/07/2025, 01/08/2025 & 06/08/2025

	Minimum Standards on fire prevention and fire safety U/R 33	D. O. E. Circular dated 17.01.2005 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			MR
	• Road width	06m	06m	MR
	• Gate width	Directly accessible	Directly accessible	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			MR
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floors	Old case	1.50m & 82cm	MR (being old case)
	• Basements	Old case	80cm & 50cm	MR (being old case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	Old case	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	Old case	01m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	11nos	Provided	MR
	• Types	ABC/CO2	Provided	MR
	• ISI marking	ISI Marked	Provided	MR

N/12

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			NA
9	Public Address System.			NA
10	Automatic Sprinkler System.			NA
	• Basement	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	01	Provided	MR
	• Number of hydrants per floor	30m	Provided	MR
	• Hose Box	5mm	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
13	• Hose Box	NA	NA	NA
	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
14	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5000 LTR	Provided	MR
15	Exit Signage.			MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply			N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

19	Fire Control Room	• Detector System Panel	N/A	N/A	N/A
		• Flow Switch Panel	N/A	N/A	N/A
		• PA System Panel	N/A	N/A	N/A
		• Batter backup	N/A	N/A	N/A
		• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:		N/A	N/A	N/A
			N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular 17.01.2005, it is **recommended for renewal** of fire safety certificate issued vide this department letter of even no. F6/MS/DFS/2006/1716 dated 25/07/2006.

Signature of the Inspecting Officer
Name :- C.L. Meena
Designation:- ADO/RN

D.B. Mukharjee (DO/NW)

By cfo (wz)
07/08/2025

by
07/08/2025

cfo/
16/8/2025

Principal Director

CFO to Secy.

18/08/25

cfo/
20/8/2025

ADO (RN)

As approved, F.T. letter is put up for your signature please.

cfo/
21/8/2025

by
20/08/2025