

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/NDZ/2025/327

Dated:-07/07/2025

To

The General Administration,  
Department of Commerce,  
Ministry of Commerce & Industry,  
Government of India, Room No.2, B-1,  
Vanijya Bhawan, New Delhi-11.

**Sub: Regarding issuance of Fire Safety Certificate (FSC) in r/o Vanijya Bhawan (office building), 16-A , Akbar Road, New Delhi.**

Sir,

This has a reference to your mail id GA\_DOC<[moc\\_admin@nic.in](mailto:moc_admin@nic.in) dated 04.06.2025, on the subject cited above. In this regard, this is to inform you that the site was inspected by officers concerned of this department on 27/06/2025 in the presence of Sh. Arbind Choudhary from building side and following shortcomings were observed: -

1. Smoke Management found nonfunctional and also not integrated with alarm system.
2. Detectors found nonfunctional at some places.
3. Pressurization of lift lobbies & staircase is not integrated with alarm system.
4. Canteen at second basement is not allowed as per approved plan.

In view of above, fire safety certificate (FSC) cannot be renewed /issued at this stage. Therefore, you are requested to rectify the above shortcoming at the earliest under intimation to this department.

Yours faithfully

(Atul Garg)

DIRECTOR

01123414000

37