

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/2024/SZ/ 06  
To

Dated: 02/01/2025

The Authorized Signatory,  
Ansal Tower, Plot No 38,  
Flat owners Welfare Association,  
New Delhi 110019

Sub: Regarding issuance of FSC in r/o M/s Ansal Tower at Plot No 38, Nehru Place,  
New Delhi 110019.

Sir,

This has reference to your letter received through outdoor diary no 1011 dated 09/12/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 27.12.2024 in the presence of Mr. Amrish Kumar (Manager) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The fire check doors needs to be repaired / replaced in the building.
2. Electrical panel & Kitchen found installed at 7<sup>th</sup> floor in the corridor.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE