

c/22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F.6/DFS/MS/2025/NDZ/169

Dated 17/04/2025

To,

Authorized Signatory,
Ansal Imperial Tower,
Block - C, Community Centre,
Naraina Vihar, New Delhi.

Sub:- Regarding renewal of FSC in r/o Ansal Imperial Tower, Block - C, Community Centre, Naraina Vihar, New Delhi.

Sir,

This has reference to your Letter no. AHL/2025/01 dated 18/03/2025 on the subject cited above, it is to inform that the site was inspected by the officer concerned of this department on 07/04/25 in the presence of Mr. Chouhan, Maintenance Manager and the following shortcomings were observed: -

1. Electrical shafts not sealed properly.
2. Smoke management system found nonfunctional.
3. MOEFA found removed at some places, required to be provided.
4. Exits signage & Lift signage is not provided.

In view of above, the case is rejected with a request to rectify the above said shortcomings. Further, the occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:-

The Commissioner, North MCD, Civic Centre, New Delhi.