



2/92 75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/GH/2025/SZ/ 30

Dated: 15/01/2025

To

The Joint Commissioner of Police (Lic.),
1st Floor, P.S. Defense Colony
New Delhi-110049

Sub: Renewal of Fire Safety Certificate in r/o M/s Anutham Guest House located at E-147, FF, SF & TF, Saket, New Delhi-110017

Sir,

This has reference to online application No. 2024122318309 dated 24/12/2024. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on dated 06/01/2025 in the presence of Mr. Himanshu Sharma of the guest house, from fire safety point of view. During the inspection, the shortcomings observed are as below.

1. Smoke management system provided not integrated with MCPs at upper floors.
2. First-aid hose-reel provided found non-functional.
3. CO. Monoxide detector & alarm found removed.

In view of the above, the application for renewal of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety certificate/arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. Sh. Akshay M/s Anutham Guest House at E-147, FF, SF & TF, Saket, New Delhi-110017