



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/Hospital/NDZ/2025/ 564

Dated 08/04/2025

To,

Dr. M . K Sexena (Director),
Apex Citi Hospital,
D – 440, West Vinod Nagar,
Near Ras Vihar, I. P. Extn.,
Delhi – 110092.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Apex Citi Hospital located at D – 440, West Vinod Nagar, Near Ras Vihar, I. P. Extn., Delhi – 110092.

Sir,

This has a reference to Outdoor Diary No. 14361 dated 12/03/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 29/03/2025 in the presence of Dr. M.K Saxena (Director) and observed that the shortcomings intimated vide letter No. F6/DFS/MS/Hospital/2016/1554 dated 16/06/2016 (copy enclosed) has not been complied yet.,

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety requirements shall be at the risk and liability of the owner / occupier. The Licensing authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

Enclose: As above.

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Medical Superintendent, Nursing Homes, Directorate General of Health Services, Govt. of NCT of Delhi, 3rd floor, Delhi Govt. Dispensary Building, S-1, School Block, Shakarpur, Delhi – 110032.

92

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001

No.

FTG/DPS/MS/Hospital/2016/1584

Dated:

16/6/16

To,

Dr. M.K.Sexena

Apex Citi Hospital

D-440, West Vinod Nagar, Hanuman Road, Delhi-92

Sub: - Regarding NOC for Apex Citi Hospital located at D-440, West Vinod Nagar,
Hanuman Road, Delhi-92

Sir,

Please refer to letter dated 16.02.2016 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the Hospital to verify the fire safety arrangements in accordance with the 33 of the Delhi Fire Service Rule, 2010. At the time of inspection Dr.M.K.Sexena was also present and it was observed that the Hospital building is comprised of lower ground, ground plus three upper floors. The following shortcoming was observed:-

1. The width of main staircase is 1.70 m against the required width of 2 m.

In view of above, the fire safety certificate cannot be issued at this stage. Therefore you are requested to rectify the above said shortcoming under intimation to this department for further course of action.

Yours faithfully

(Virendra Singh)

Dy. Chief Fire Officer

ofc Rn

