

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**


No. F6/DFS/MS/EH/WZ/2026/59

Dated: 21/01/2026

FIRE SAFETY CERTIFICATE

Certified that the **M/s Apni Rasoi at Shop no F-18, Ground Floor, Vijay Nagar, Hudson Lane Delhi – 110009**. Comprised of Basement Ground Plus Two Upper Floors Basement – Vacant, 1st & 2nd Floor- Residential. **(Restaurant running at Ground Floor only)**. The premises was inspected by the officer concerned of this department on **13/01/2026** in the presence of **Mr. Mohit, Manager** and found that the said restaurant premises has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class - **Assembly Building (Group D), Restaurant running at Ground floor only**, with effect from**21/01/2026**.....for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued **21/01/2026** at New Delhi by.



(S. K. Dua)

Dy. Chief Fire Officer

Copy to: -

o/r

1. The Commissioner, MCD, Civic Centre, New Delhi.: Online ID – 2025122215995 Dated 22.12.2025.
2. The Manager, M/s Apni Rasoi at Shop no F-18, Ground Floor, Vijay Nagar, Hudson Lane Delhi – 110009

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. Any deviation w.r.t. construction, electric installation, set bac area etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT				
1.	Name & address of the building	M/s Apni Rasoi at Shop no F-18, Ground Floor, Vijay Nagar, Hudson Lane Delhi – 110009.		
2.	Type of occupancy	Assembly Building (Restaurant) – Group -D		
3.	Building is Comprised of	Basement Ground plus Two Upper Floors Basement – Vacant, 1 st & 2 nd Floor- Residential. (Restaurant running at Ground Floor only)		
4.	Type of case	Renewal		
5.	Details of previous FSC No.	F6/DFS/MS/2022/EH/259 Dated 14/09/2022		
6.	Fire safety directives No.-	NBC Part - 4/BBL		
7.	Date of inspection: -	13/01/2026		
8.	Name of the inspecting officer: -	Sh. Kaushal Kishore, ADO (SJ)		
9.	Name & designation of officer From the building side: -	Sh. Mohit, Manager		
10.	Year of construction: -	1965		
11.	Applicant's letter No: -	Online MHA Portal ID. No- 2025122215995 dt. 22/12/2025		
S. No.	Minimum Standards on fire Prevention and fire safety U/R	Requirement/ Fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building	Restaurant running at GF.		
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	09 mtr.	12 mtr.	MR*
		N/A	N/A	N/A
		N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits	Restaurant running at GF.		
	a. Number of staircases	Restaurant running at GF.		
	<ul style="list-style-type: none"> Upper floors Basements 	N/A	N/A	N/A
		N/A	N/A	N/A
	b. Width of staircase	Restaurant running at GF.		
	<ul style="list-style-type: none"> Upper floors Basements 	N/A	N/A	N/A
		N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No. of continuous staircase to terrace			
		N/A	N/A	N/A
	e. Width of corridor			
		N/A	N/A	N/A
	f. Door size	2 X 1.50 mtr.	2 X 1.50 mtr.	MR
3.	Compartmentation	Restaurant running at GF.		
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts 	N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire rating of shaft door Water curtain Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System	Restaurant running at GF.		
	<ul style="list-style-type: none"> Basements Upper floors (Ground Floor) 	N/A	N/A	N/A
		Required	Provided Natural	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	04 nos.	06 nos.	MR
		ABC/CO ₂ /W.CO ₂	ABC & CO ₂	MR
		Required	Provided	MR
6.	First-Aid Hose Reel			
	<ul style="list-style-type: none"> Total number of each floor Length of hose reel hose Nozzle diameter 	01 no.	01 no.	MR
		30 mtr.	30 mtr.	MR
		5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System.			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A

	<ul style="list-style-type: none"> • Location of main panel • Location of repeater panel • Alternate source of power • Hooter's Location 	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Basement • Upper floors • Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose box per floor 	100 mm 01 no. 01 no.	100 mm 01 01	MR MR MR
12.	Yard Hydrants	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Total number of hydrants • Hose box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangement			
	Ground level			
	<ul style="list-style-type: none"> • Discharge of main pump • Head of main pump • Number of main pumps • Jockey pump out put • Jockey pump head • Stand by pump output • Stand by pump head • Auto starting/Manual stopping 	N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A
	Terrace level			
	<ul style="list-style-type: none"> • Discharge of pump • Head of pump • Power supply • Auto starting of pump 	450 LPM 40 mtr. Required Required	450 LPM 40 mtr. Provided Provided	MR MR MR MR
14.	Captive Water Storage for Fire Fighting			
	<ul style="list-style-type: none"> • Underground tank capacity • Draw-off connection • Fire service inlet • Access to tank • Overhead tank capacity 	N/A N/A N/A Required 20,000 Ltrs	N/A N/A N/A Provided 20,000 Ltrs	N/A N/A N/A MR MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft • Pressurization of lift lobby • Communication in lift car • Fireman's switch • Lift signage 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> • Total area • Location 	N/A N/A	N/A N/A	N/A N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector system panel • Flow switch panel • PA system panel • Battery backup • Building floor plan 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A

20.	Special Fire Protection System for Protection of special Risk, if any:	N/A	N/A	N/A
-----	--	-----	-----	-----


*PNF – Provided but Non-Functional, *MR – Meeting Requirement,

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measure as required under the rules, if approved, we may renew the FSC issued vide letter no. F/6/DFS/MS/2022/EH/259 Dated 14/09/2022 to said restaurant. The last date of deemed approval is 20/01/2026.

Accordingly, DFA is prepared and put up for kind perusal and signature please.

Signature of the Inspecting Officer



Name :- Sh. Kaushal Kishore
Designation : ADO (SJ)

~~DO/WD~~ ~~Approved~~
18/11/2026

~~By CFO (WZ)~~ ~~LIV~~
19/01/26

~~Pr. Director~~

~~DO. CFO to S. S. S.~~

~~My. CFO (WZ)~~ ~~19/01/26~~
~~F.T. Please~~
~~LIV~~
~~20/01/26~~

~~ADO (SJ)~~

~~20/01/26~~

FT Letter is prepared and put up for sign. pl.

~~DO/WD~~
~~F.P. wing~~

~~LIV~~
~~20/01/26~~

~~W. Headed~~
~~20/01/26~~

~~20/01/26~~
ADO (SJ)