



6/5

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F.6/DFS/MS/2023/EH/SZ/ 310

Dated: 15/07/2025

To,

Mr. Ashish Goyal  
M/s Apni Rasoi (A Unit of DA Apni Rasoi Dine In LLP)  
Property no. 452 and 453, Kh. No. 1/5 and & 21/3 G. F.,  
Vill. Kakrola, Kakrola Housing Complex,  
Delhi-1110078.

**Subject:-Regarding issuance of Fire Safety Certificate in r/o M/s Apni Rasoi (A Unit of DA Apni Rasoi Dine In LLP) located at Property no. 452 and 453, Kh. No. 1/5 and & 21/3 G. F. Station, Vill. Kakrola, Kakrola Housing Complex, Delhi-110078.**

Sir,

This has reference to MCD application ID No. 2025061810252 dated 18/06/2025 on the subject cited above. In this connection, the premises was inspected by the officer concerned of this department on dated 11/07/2025 in presence of Mr. Shyam (Manager). The Eating House is running ground floor and building comprised of ground plus three upper floors. The following shortcoming was observed during the time of inspection.

1. Fire check door shall be required in the kitchen.
2. An additional door of width 1.50 meters shall be required.
3. First Aid Hose reel is not provided.
4. MOEFA is not provided.
5. Down-comer is not provided.
6. Fire pump at terrace level 450 lpm head 40 meters is not provided.
7. Over Head tank capacity 20,000 liters is not provided.
8. Exit signages are not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

MCD ID No. 2025061810252 for online upload