



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/EH/NDZ/2025/ 199

Dated:

05/05/2025

To,

The Joint Commissioner of Police (Lic.),
First Floor, Police Station Defence Colony,
New Delhi – 110024.

Subject: - Regarding grant of Fire Safety Certificate in r/o Apni Rasoi (A Unit of Shiv Shakti Enterprises located at Property No. RZF-1/3, Mahavir Enclave, Main Palam Dabri Road, Dwarka, Delhi – 110045.

Sir,

This has a reference to your MCD Portal application No. 202540705783 dated 11/04/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 26/04/2025 in the presence of Mr. Neeraj Kumar (Manager) and observed that building comprised of Basement, Ground plus two upper floors. Basement (Grocery shop), ground (restaurant), first floor (Swiggy Warehouse), Second floor (GYM). **(But Restaurant running on ground floor only.**

Following shortcomings were observed during time of inspection:

1. One door Entry /Exit of width 1.80 meter are provided against requirements of two doors width 1.50 meters each.
2. Smoke Management System not provided.
3. Fire extinguishers not provided.
4. First-Aid-Hose Reel not provided.
5. MOEFA not provided.
6. Internal Hydrants not provided.
7. Terrace level fire pump capacity of 450 LPM not provided.
8. Terrace fire water tank of 20,000 liters not provided.
9. Exit & floors Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours

faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE

SERVICE

Copy to:-

1. The Manager, Apni Rasoi (A Unit of Shiv Shakti Enterprises located at Property No. RZF-1/3, Mahavir Enclave, Main Palam Dabri Road, Dwarka, Delhi – 110045