

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No: F6/DFS/MS/Hospital/WZ/2025/ 378

Dated: 09/07/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s. Apollo Cradle (A unit of Apollo Specialty Hospitals PVT. Ltd. Located at 15A, Shivaj Marg, Najafgarh Road, New Delhi-110015, comprised of 02 Basement + Ground + 03 Upper Floors. The premises was inspected by the officers concerned of this department on 01/07/2025, in the presence of Sh. Kamal Rathee and found that the premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class Group C (Institutional) with effect from 09/07/2025.... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/07/2025 at New Delhi.

(Atul Garg)
Director

Copy to:-

1. The Directorate General Health Service (DGEHS), Govt. of NCT of Delhi, F-17, Karkardooma, New Delhi- 110032.
2. The Medical Superintendent, Apollo Cradle (A unit of Apollo Specialty Hospitals PVT. Ltd. Located at 15A, Shivaj Marg, Najafgarh Road, New Delhi-110015.
3. The Executive Engineer (Building.) Municipal Corporation of Delhi, Office, Karol Bagh, Anand Parbat New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The basement & upper floor shall be used as per building bye laws & sanctioned plan. If it used other than sanctioned plan, FSC will be automatically null & void strictly.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1.	Name & address of the building	Apollo Cradle (A unit of Apollo Speciality Hospitals PVT. Ltd. Located at 15A, Shivaj Marg, Najafgarh Road, New Delhi-110015.
2.	Type of Occupancy	Institutional (Hospital)
3.	Type of Case	New
4.	Details of previous NOC	Nil
5.	Fire Safety directives letter No	F.6/DFS/MA/BP/2022/02 dated 04.01.2023
6.	Date of inspection	01/07/2025
7.	Name of the Inspecting Officers	M.K.Chattopadhyay Dy.CFO(WZ) & Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	Sh. Kamal Rathee, Fire Officer
9.	Year of Construction	2023
10.	Applicant's letter No.	Outdoor dairy No.2964 dated: 23/06/2025

The said hospital is comprised of 02 basement + ground + 03 upper floors.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	9 mts	Provided	MR
	• Gate width	6 mts	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03	Provided	MR
	• Basements	02	Provided	MR
	b. Width of staircases			
	• Upper Floors	2X2m, 1X1.5m	Provided	MR
	• Basements	02 X 1.5m	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	Provided in 01 staircase	NA
	d. No. of continuous staircases to terrace	02	Provided	MR
	e. Width of Corridor	2.4 mts	Provided	MR
	f. Door Size	2 x 2 mts, 1 x 1.5 mts	Provided	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	Required	Provided	MR
4	Smoke Management System.			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	35 nos.	Provided	MR
	• Types	CO ₂ , DCP, ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30 m required	Provided	MR
	• Nozzle diameter	5 mm required	Provided	MR

7	Automatic fire detection and alarming system			MR
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	
10	Automatic Sprinkler System.			MR
	• Basement	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			MR
	• Size of riser/down-comer	150mm	Provided	MR
	• Number of hydrants per floor	02	Provided	MR
	• Hose Box	02	Provided	MR
12	Yard Hydrants.			MR
	• Total number of hydrants	04	Provided	MR
	• Hose Box	04	Provided	MR
13	Pumping Arrangements.			
	• Ground Level	2 x 2280 LPM	Provided	MR
	➤ Discharge of main Pump	40 m	Provided	MR
	➤ Head of Main pump	01	Provided	MR
	➤ Number of main pumps	180 LPM	Provided	MR
	➤ Jockey Pump out put	40 m	Provided	MR
	➤ Jockey pump head	2280 LPM	Provided	MR
	➤ Standby Pump out put	40 m	Provided	MR
	➤ Standby Pump Head	Required	Provided	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access			
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump			
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	1,50,000 ltrs	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR

8	Refuge Area.			
	Total Area	NA	NA	NA
	Location	NA	NA	NA
19	Fire Control Room	NOT REQUIRED		
	• Detector System Panel	NA	Provided	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	Provided	NA
	• Batter backup	NA	Provided	NA
	• Building Floor Plans	NA	Provided	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required LT & HT Panel	Flooding system Provided	MR

The Fire Protection system provided in the building found in good working condition at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

00/mv
3/07/2015

[Signature]
07/07/2015

Signature of the Inspecting Officer
Name: - M. K. Chattopadhyay
Designation: - Dy.CFO (WZ)

[Signature]
03/7/2015

Signature of the Inspecting Officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)

741 WZ
dated 02/02/2015

CFO | *[Signature]*
7/7/2015
[Signature]
Director
[Signature]
07/7/15

[Signature] ADO/mv

Sir, F.T is put up for your kind personal & signature pls.

[Signature]
Director
[Signature]

[Signature]
09/7/2015