

C-43

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
CONNAUGHT PLACE: NEW DELHI-110001

No. F.6/DFS/MS/2025/SZ/370

Dated: 04/07/2025

FIRE SAFETY CERTIFICATE

Certified that the building of M/s **Apollo Athenaa Women's Cancer Centre** located at Plot No. E-2, Defence Colony, New Delhi-110024, comprised of Basement, Stilt, Ground & 03 upper floors, owned/occupied by A Unit of Apollo Hospitals Enterprise Limited, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on dated 30/06/2025 in the presence of Dr. Shaloo Varma (VP & Unit Head) & other technical staff and that the said building/premises is fit for occupancy class "**Institutional, Group-C**" (Nursing Home) with effect from 04/07/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 04/07/2025 at New Delhi by


(ATUL GARG)
DIRECTOR
Delhi Fire Service

Copy to: -

1. The Medical Superintendent-Nursing Home, Govt. of NCT of Delhi, Directorate General of Health Services (Nursing Home Cell), 3rd Floor, Delhi Govt. Dispensary Building, S-1, School Block, Shakarpur, Delhi-110092
2. The Assistant Engineer (Bldg.)-II, Central Zone, Building Department, Municipal Corporation of Delhi, Jal Vihar, Lajpat Nagar, New Delhi-110024
3. Dr. Shaloo Varma, Vice President & Unit Head, Apollo Athenaa Women's Cancer Centre (A Unit of Apollo Hospitals Enterprise Ltd), E-2, Defence Colony, New Delhi-110024

Conditions for the validity of Fire Safety Certificate:

1. The temporary use of terrace for storage of engineering material shall be cleared within a month and access to terrace floor shall be restricted to authorized personnel only, as undertook vide letter dated 30.06.2025.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
8. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name & Address of the Building	M/s Apollo Athenaa Women's Cancer Centre (A Unit of Apollo Hospitals Enterprises Ltd) located at Plot No. E-2, Defence Colony, New Delhi-110024		
2	Type of Occupancy	Institutional Building "C" (Nursing Home)		
3	Building Comprised of	Basement, Stilt, Ground + 03 Upper Floors		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/2025/199 dated 09/06/2025		
7	Date of Inspection	30/06/2025		
8	Name of the Inspecting Officers	ADO (SJ) As per direction		
9	Name & Designation of Officers from the building side	Dr. Shaloo Varma (VP & Unit Head) & other technical staff		
10	Year of construction	2025		
11	Applicant letter No.	No. Nil dated 24/06/2025 received through outdoor diary No. 3012 dated 24/06/2025		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC/UBBL Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	09 mtr	12.19 mtr	MR
	• Gate width	N/A	Abuts on road	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	➤ Upper floors	02 Nos	02 Nos	MR
	➤ Basement floor	02 Nos	02 Nos	MR
	b. Width of Staircase			
	➤ Upper floors	2m & 1.5m	2m & 1.5m	MR
	➤ Basement floor	2m & 1.5m	2m & 1.8m	MR
	c. Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	Required	Provided	MR
	d. No. of continuous staircase to terrace	02 Nos	Provided	MR
	e. Width of corridor	2.40 mtr	Provided	MR
	f. Door size	1.25m / 2m	Provided	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	02 Hr	Provided	MR
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	Required	Provided	MR
4	Smoke Management system.			
	• Basement	12 ACPH	Provided	MR
	• Upper floors	12 ACPH	Provided	MR
5	Fire Extinguishers.			
	• Total numbers	Required	18 Nos	MR
	• Types	ABC / CO ₂	ABC & CO ₂	MR
	• ISI Marking	Required	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	One	One	MR
	• Length of hose-reel hose.	30m	30m	MR
	• Nozzle Diameter	5mm	5mm	MR

7	Automatic Fire Detection and Alarming system.			
	<ul style="list-style-type: none"> Type of detectors (Smoke) Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Smoke / Heat	Provided	MR
		Ground floor	Provided	MR
		N/A	N/A	N/A
		Required	Provided	MR
		Each floor	Provided	MR
		Required	Provided	MR
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	150 mm	Provided	MR
		One	Provided	MR
		Required	Provided	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump House Access Terrace Level Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	2280 LPM	Provided	MR
		70 mtr	Provided	MR
		01 No.	Provided	MR
		180 LPM	Provided	MR
		70 mtr	Provided	MR
		2280 LPM	Provided	MR
		70 mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14.	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	1,50,000 Ltr.	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10,000 Ltr.	15,000 Ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	N/A	N/A	N/A
		N/A	N/A	N/A

W-7

19.	Fire Control Room.			
	• Detector system panel.	Required	Provided	MR
	• Flow switch panel.	Required	Provided	MR
	• PA system panel.	N/A	N/A	N/A
	• Battery backup	Required	Provided	MR
	• Building floor plan	Required	Provided	MR
20.	Special fire protection system for protection of special risk, if any.	Required	Provided ABC & CO ₂ fire extinguisher near elect. Panel.	MR

Note: The access to the terrace floor shall be restricted to general public except concerned & authorized staff and the engineering material stored at terrace shall be cleared within a month by the management, if agreed please.

The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection. In view of the substantial compliance of the minimum standards on fire prevention and fire safety as required under the rules, issue of the fire safety certificate, under rule 35 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for perusal/approval & signature please.

Signature of the Inspecting Officer
Name: Sahtosh Kumar
Designation: ADO (SJ)

DO (SD)

on act. duty to U.S

CFO

3/7/2015

Director

3/7/15

KI PL

Adl/Sj

Sir, F.T letter is put up for your sig. pl

Director

3/7/15