

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6/DFS/MS/2025/School/WZ/ 1222

Dated 06/10/2025

## FIRE SAFETY CERTIFICATE

Certified that the The Arihant School located at Ishwar Colony, Bawana, Delhi-110039 comprised of Ground and First floor was issued FSC by this department vide letter No F6/DFS/MS/2022/School/WZ/1172 dated 20.10.2022. The premises was re-inspected by the officer concerned of this department on 25.09.2025 in the presence of Sh. Santlal (Chairman), and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/premise is fit for occupancy Group B Educational with effect from ... 66.110.120.25... for a period of three years, subject to compliance of the conditions mentioned below:

Issued on .. 06.1012025 at New Delhi by

(M.K. Chattopadhyay)
Dy. Chief Fire Officer

Copy to:-

- 1. The Director, Education, Government of NCT of Delhi. Old Sect. Delhi-110054
- 2. The Principal, The Arihant School located at Ishwar Colony, Bawana, Delhi-110039.

Conditions for the validity of Fire Safety Certificate:

- 1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
- 2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3. The trained fire fighting staff should be available round the clock.
- 4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <a href="www.dfs.delhigovt.nic.in">www.dfs.delhigovt.nic.in</a>
- 8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT Name & address of the building: The Arihant School located at Ishwar Colony, Bawana, Delhi- 110039. Type of Occupancy Educational 3. Building Comprised of Ground plus first floor 4. Type of Case Renewal 5. Details of Previous NOC F6/DFS/MS/2022/School/WZ/1172 dated 20/10/2022 6. Fire Safety directives letter No DOE circular No. 3298-3398 dated 01/03/2011 Date of inspection 25/09/2025 8. Name of Inspecting Officer R.K.Sinha, ADO (BW) 9. Name and designation of officers From the building side Sh. Santlal (Chairman) 10. Year of Construction 2018 11. Applicant's letter No. Outdoor Diary No. 5866 dated 12/09/2025 Minimum Standards on fire S. prevention and fire safety U/R 33 DOE No. Provided at site Remarks Requirement 1. Access to building MR/NMR Road width 6 m Gate width Provided 4.5 m MR Width of internal road Directly Accessible MR NA 2. Number, Width, Type & Arrangement of Exits NA NA a. Number of staircases Upper Floors 02 Basements Provided MR b. Width of staircases NA NA NA Upper Floor 1.50 m each Basements 1.70 m & 1.60 m c. Protection of exits NA MR NA Fire check door NA NA Pressurization NA NA d. No. of continuous staircases to NA NA terrace NA NA Width of Corridor NA NA NA Door Size NA 3. 1 m Compartmentation NA Provided Fire check door MR NA Sealing of electrical shafts NA Fire Rating of shaft door NA NA Water Curtain NA NA NA Fire Dampers NA NA 4. Smoke Management System NA NA NA NA Basements NA NA Upper floors NA NA 5. Required Fire Extinguishers Naturally Ventilated NA Total numbers MR Types 03 Nos. IS marking 6. First-Aid Hose Reels ABC/ CO2 Type Provided MR Provided Total numbers on each floor Required MR Provided Length of hose reel hose MR Nozzle diameter NA NA 7. Automatic fire detection and alarming system NA NA NA NA NA NA Location of Main Panel NA • Location of Repeater Panel NA Alternate source of power NA NA NA NA • Hooters Location NA NA NA NA NA NA NA NA NA NA

		NIO	NA	2.0
		NA	NA	NA
8.	MOEFA System	NA		
9.	Public Address System			
10	Automatic Sprinkler System			NA NA
10.	Automatic op	NA	NA	NA
	Basement	NA	NA	NA
	Ground Floor	NA	NA	1474
	Sprinkler above false ceiling			
••	Internal Hydrants			NA NA
11.		NA	NA	NA NA
	Size of riser/down-comer	NA	NA	NA NA
	Number of hydrants per floor	NA	NA	INA
	Hose Box			
12.	Yard Hydrants			
	Total number of hydrants	NA	NA	NA NA
	- n	NA	NA	1.7.2
	Hose Box     Pumping Arrangements			
13.	Pumping Arrangements			
	Ground Level	X 7 1	NA	NA
	Discharge of main Pump	NA NA	NA NA	NA
	➤ Head of Main pump	NA	****	
	March Control	NA	NA	NA
	Number of main pumps	NA	NA	NA
	> Jockey Pump out put	NA	NA	NA
	<ul> <li>Jockey pump head</li> <li>Standby Pump out put</li> </ul>	NA	NA	NA
		NA	NA	NA
	> Standby Pump Head > Auto Starting/Manual	NA	NA	NA
	Stopping		3.01	NA
	> Pump House Access	NA	NA	NA
	Terrace level			
		NIA I	NA	NA
	Discharge of pump	NA NA	NA	NA
	> Head of the pump	NA		
	> Power Supply	NA	NA	NA
	> Auto Starting of pump	NA	NA	NA
14.	Captive Water Storage for fire fighting			
	Underground tank capacity	NA	NA	NA
	> Draw-off connection	NA	NA	NA
	> Fire service inlet	NA	NA	NA
	> Access to tank	NA	NA	NA
	Overhead Tank capacity	NA	NA	NA
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	Pressurization of Lift Shaft	NA	NA	NA
		NA NA	NA	NA
	Pressurization of Lift lobby     Communication In lift Car	NA NA	NA	NA
		NA NA	NA	NA
	Fireman's Grounding Switch		NA	NA
	Lift Signage	NA	NA NA	NA
17.	Standby power supply	NA	NA	
18.	Refuge Area.			
	> Total Area	NA	NA	NA NA
	> Location	NA	NA	NA
	Fire Control Room			

Detector System Panel	la - 11		
Flow Switch Panel	NA	NA	
PA System Panel	NA	NA NA	NA
Battery backup	NA	NA.	NA
Building Floor Plans	NA	NA NA	NA
Special Fire Protection S	NA		NA
pecial Fire Protection System for Protection of special Risks, if any:	NA	NA	NA
reside Risks, II any:		NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 3298-3398 dated 01/03/2011, it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/2022/School/WZ/1172 dated 20/10/2022.

> Signature of Inspecting Officer Name: Rajeev Kumar Sinha Designation: ADO/B.W.

Do (Na) - Brown of 4000 -

Principal Atrector Dy. Cfo to de Dy. CFo(W2)

Dy. CFo(W2)

Oshiolo

Str., FoT letter in putup for signifling

Dus poolsw