



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-7
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2025/ 171

Dated: 26/03/2025

To,

The Principal,
Anuj Public School
B - 4/257, Nehru Vihar, 25 Futa Road,
Mustafabad, Delhi – 110094.

Subject: - Regarding grant of Fire Safety Certificate in r/o Anuj Public School located at B - 4/257, Nehru Vihar, 25 Futa Road, Mustafabad, Delhi – 110094.

Sir,

This has a reference to your Outdoor diary No. 12669 dated 17/02/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 13/03/2025 in the presence of Mrs. Munisha Devi (Manager) and observed that building comprised of ground plus two upper floors.

Following shortcomings were observed during time of inspection:

1. II nd staircase found removed. One fire escape of width 0.75 m is required to be provided.
2. First-Aid-Hose Reel provided but not functional.
3. Fire pump of 450 LPM not provided.
4. Over head water storage tank of capacity 5,000 liters found removed.
5. Exit & floors Signage's found removed at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

ok DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, MCD Civic Centre, Jawahar Lal Nehru Marg, New Delhi-110002.