



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5
आफ़ादी का
अमृत महोत्सव

C-21

No.F6/DFS/MS/School/SZ/2025/655

Dated: 19/08/2025

To

The Principal,
Arpan Public School,
J-11, Jaitpur Extension, Badarpur,
New Delhi-44.

Sub:- Regarding renewal of Fire Safety Certificate in respect of **Arpan Public School** located at **J-11, Jaitpur Extension, Badarpur, New Delhi-44.**

Sir,

With reference to the letter bearing outdoor diary no. 2847 dated 18.06.2025 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 11.08.2025 in the presence of manager and it was observed that the school is running on Ground + 01 upper floor of the building comprised of Ground + 02 upper floors & 2nd floor is partial semi pucca constructed and other half under construction. The following shortcomings were observed during the inspection.

1. Hose reel found non functional and is not adequate.
2. Fire pump found non functional.
3. Terrace Tank is not adequate in capacity.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Virendra Singh)
Chief Fire Officer

9/8/25

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.