



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5  
आजादी का  
अमृत महोत्सव  
C-35

No. F6/DFS/MS/School/NDZ/2025/ 332

Dated: 05/05/2025

The Principal,  
Arunodaya Public School  
1- A, Institutional Area,  
Vikas Marg, Karkardooma,  
Delhi - 110092.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Arunodaya Public School located at 1- A, Institutional Area, Vikas Marg, Karkardooma, Delhi - 110092.**

Sir,

This has a reference to your Outdoor Diary No. 14267 dated 10/03/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 09/04/2025 in the presence of Mrs. Rupik Tandon (Principal) and observed that building comprised of Basement, Ground plus three upper floors.

**Following shortcomings were observed during time of inspection:**

1. Pipeline of down comer and hose reel hose found totally damaged.
2. Automatic Sprinkler system found not functional.
3. Fire pumps found defective.
4. Only one over head water tank of capacity 4,000 liters provided. 2<sup>nd</sup> tank found damaged/empty.
5. Exit & floors Signage's not provided at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

23/05/2025

(VIRENDRA SINGH)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to:- for information and necessary action.

1. The Director of Education, Old Secretariat, Civil Lines, Delhi-110054.