



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/2025/School/ 725
To,

Dated: 11/09/2025

Mr. Sunil Kuamr (Manager),
Arya International School,
C-Block, Rama Vihar (Rohini Sector-39),
New Delhi-110081.

Sub: Issue of FSC in r/o Arya International School, C-Block, Rama Vihar (Rohini Sector-39), New Delhi-110081.

Sir,

This is in refer to your letter No. 1/2025 dated 17.07.2025 received through outdoor diary no. 3851 dated 17.07.2025 on the subject cited above. In this connection this is to inform you that the above said school building was inspection by the officer concerned of this department on 14.08.2025 to ascertain the availability and operability of the fire prevention and fire safety measures, Mr. Sunil Kumar (Manager), was present at the time of inspection. During the course of visit it was observed that building building is comprised of ground + one upper floor. The following shortcomings were observed:

1. First Aid hose reel not provided.
2. Terrace pump of 450 lpm is not provided by the owner of the building.
3. An overhead water storage tank capacity of 10,000 ltr is not provided
4. The required exit signage are not provided.
5. Copy of approved/ as built plans & proof of year of construction school building may kindly be provided.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully


10/9/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054