



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001




No. F6/DFS/MS/2025/School/ 964

Dated: 08/08/2025

FIRE SAFETY CERTIFICATE

Certified that the Arya Model School located at Arya Samaj, Adarsh Nagar, Delhi-110033 comprised of Ground & 03 upper floors owned/ occupied by Arya Model School was issued Fire Safety Certificated vide this office letter no. F6/DFS/MS/School/2022/NWZ/803 dated 28/07/2022. The premise was inspected by the officer concerned of this department on 29/07/2025 in the presence of Sh. Sanjay Soni (Hony. Manager) and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy class "Group B Educational (School)" with effect from08/08/2025 for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on08/08/2025 at New Delhi by.


Virendra Singh
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Deputy Director of Education, Zone-VII, District North Lucknow Road, Timarpur, Delhi - 110054. .
2. The Manager, Arya Model School located at Arya Samaj, Adarsh Nagar, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Arya Model School, Arya Samaj, Adarsh Nagar, Delhi-110033.
2. Type of Occupancy : Educational (School)
3. Composition of building : Ground & 03upper Floors
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/School/2022/NWZ/803 dated 28/07/2022
6. Fire Safety directives letter No : Nil
7. Date of inspection : 29/07/2025
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Mr. Sanjay Soni (Hony. Manager)
10. Year of Construction : 1983
11. Applicant's letter No. : Letter No. Nil & DFS Dairy No. 3824 dated: 16/07/2025

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06 m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.18m & 1.06m	MR (being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	01m	1.m including door fitting/chowkhat	MR(being old case)
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	12nos	12nos	MR
	• Types	ABC/Co2	ABC-10/ Co2-02	MR
	• ISI marking	ISI Marked	Yes	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40m	Provided	MR
➤ Power Supply	Required	Provided	MR	
➤ Auto Starting of pump	Required	Provided	MR	
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 LTR	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A

N/20

18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-IV, it is **recommended for renewal** of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/School/2022/NWZ/803 dated 28/07/2022.

Signature of the Inspecting Officer

Name :- C.L. Meena

Designation:- ADO/RN

D.B. Mukharjee (DO/NW)

DCFO/304-NW.....

Dated 30/03/25.....

Principal Director

Cfo to Scom.

ADO (RN)

As approved, F.T. letter is put up for your signature please.

CFO

4/8/2025

ms cell

07/08/2025
ADO(RN)