

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/Auditorium/ 2025/SZ/371
To

Dated 11/08/2025

Arya Orphanage, Arya Auditorium
(Formerly Lalit Suri Auditorium)
Des Raj Campus, C-Block,
East of Kailash, New Delhi - 110065

Sub: - Regarding issuance of fire safety certificate in r/o Arya Orphanage, Arya Auditorium
(Formerly Lalit Suri Auditorium) Des Raj Campus, C-Block, East of Kailash, New
Delhi - 110065

Sir,

This has reference to your letter no nil dated 14-07-2025, received through outdoor diary 15/07/2025 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 24.07.2025 in the presence of Mr. Neeraj Kumar to verify the fire safety measures installed in the building. During inspection, following points were observed:

- 1 First Aid Hose reel hose found non- functional.
- 2 Manual Operated Electrical Fire Alarm (MOEFA) system found non functional.
- 3 Automatic sprinkler system found non- functional in the basement and upper floor.
- 4 Internal hydrants and yard hydrant found non- functional.
- 5 Electrically pump capacity of 2800 LPM, & one jockey pumps of 180 LPM with 60 m head found non- functional
- 6 Terrace level pump capacity 450 LPM found non- functional.
- 7 Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully


(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
