

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE Connaught Place: New Delhi-110001

No. F.6/DFS/MS/2025/BP/ \\3

Dated: 19/03/2025

To,

The Executive Engineer (Bldg.) HQ Municipal Corporation of Delhi, 9th floor, Civic Centre, Minto Road New Delhi 110002.

Subject: Regarding clearance of building plans from fire safety point of view in r/o Arya Samaj Saket, Block-D, Saket, New Delhi.

Sir,

Please refer your ID No. 10120137 dated 09.03.2025 on the above cited subject. In this connection, this is to inform you that the matter is examined and following shortcomings are observed:

- 1. The width of corridor on the plans is not as per clause 7.11.2 of UBBL 2016.
- 2. The staircases is not segregated as per clause 7.11(t) of UBBL 2016.
- 3. Width of 01 staircases/exits is not as per clause 8.4.3 of modified UBBL 2016.
- 4. Design of staircase is not as per 7.11 of UBBL 2016.

Accordingly the case cannot be examined and therefore rejected.

Yours faithfully

Director 011 23414000

0 ल